

*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

**SCE**

RECEIVED  
NRC

REGIONAL FILE

TELEPHONE  
(714) 492-7700

H. B. RAY  
STATION MANAGER

March 24, 1983

U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362  
14-Day Follow-Up Report  
Licensee Event Report No. 83-019 (Docket 50-361)  
Licensee Event Report No. 83-023 (Docket 50-362)  
San Onofre Nuclear Generating Station, Units 2 & 3

Reference: Letter, H.B. Ray (SCE) to R. H. Engelken (NRC),  
dated March 11, 1983

The referenced letter provided you with confirmation of our prompt notification, pursuant to Sections 6.9.1.12.i of Appendix A, Technical Specifications to Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3, respectively, involving the Reactor Protection System (RPS).

Pursuant to Section 6.9.1.12, this submittal provides the required 14-day follow-up report and copies of Licensee Event Reports (LER's). Enclosed LER 83-019 (Docket 50-361) and LER 83-023 (Docket 50-362) address these events.

The referenced letter indicated that the failure in Unit 3 was on March 3, 1983, whereas it was on March 1, 1983. Also, the total number of Reactor Trip Breakers is nine (9) per unit instead of the eight (8) previously stated.

8304110194 830324  
PDR ADOCK 05000361  
S PDR

IE-22  
83-140

March 24, 1983

If there are any questions regarding the above, please contact me.

Sincerely,



Enclosure: LER 83-019 (Docket 50-361)  
LER 83-023 (Docket 50-362)

cc: A.E. Chaffee (USNRC Resident Inspector, Units 2 and 3)  
R.J. Pate (USNRC Resident Inspector, Units 2 and 3)

U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement

U.S. Nuclear Regulatory Commission  
Office of Management Information and Program Control (MIPC)

Institute of Nuclear Power Operations (INPO)