



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 31, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Units 1 and 2
License No. NPF-13
Docket Nos. 50-416/417
File 0260/15525/15526
PRD-81/44, Interim Report No.
7, Valves And Actuators Not
Manufactured Under a QA
Program
AECM-83/0215

References: 1) AECM-82/433, 10/1/82
2) AECM-82/279, 6/15/82
3) AECM-82/177, 4/20/82
4) AECM-82/97, 3/15/82
5) AECM-82/45, 1/29/82
6) AECM-81/470, 11/30/81

On October 29, 1981, Mississippi Power & Light Company notified Mr. P. A. Taylor, of your office, of a Potentially Reportable Deficiency (PRD) at the Grand Gulf Nuclear Station (GGNS) construction site. Originally, the investigation was concerned only with unqualified Bettis Air Actuators on Henry Pratt Valves.

As previously stated, we have completed our investigation for these type valves and actuators and have determined that it is not reportable under the provisions of 10CFR50.55(e). We also investigated the possibility that other type valve actuators and appurtenances may not have been manufactured under a QA program.

As per reference 1) the investigation for the BOP scope of supply has been completed. Although some of the actuators and appurtenances were not manufactured under a QA program, they have been qualified by tests and/or analyses and do not represent a reportable deficiency under 10CFR50.55(e).

8304110261 830331
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 27


Mr. J. P. O'Reilly
NRC

AECM-83/0215
Page 2

MP&L has no additional information to offer at this time other than that our investigation of valve appurtenances for the NSSS scope of supply is continuing.

A Final Report is expected to be submitted by July 8, 1983.

Yours truly,



ACP:dr

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. G. B. Taylor
South Miss. Electric Power Association
P. O. Box 1589
Hattiesburg, MS 39401