



Carolina Power & Light Company

Brunswick Steam Electric Plant  
P. O. Box 10429  
Southport, NC 28461-0429

April 1, 1983

FILE: B09-13510C  
SERIAL: BSEP/83-1083

Mr. James P. O'Reilly, Director  
U. S. Nuclear Regulatory Commission  
Region II, Suite 3100  
101 Marietta Street N.W.  
Atlanta, GA 30303

BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 1  
DOCKET NO. 50-325  
LICENSE NO. DPR-71  
SPECIAL REPORT PER TECHNICAL SPECIFICATION 3.7.8

Dear Mr. O'Reilly:

During a Unit No. 1 refueling outage, fire barrier LCO, 1-83-110, was generated to permit the performance of work required for installing a modification on Service Water System screen wash pump 1A. Due to the complexity of the work involved with this modification, the seven-day specified time frame of the LCO has been exceeded. Until the completion of the involved modification work and cancellation of the subject LCO, appropriate stationed fire watches will remain in effect. This report is submitted pursuant to Technical Specification 6.9.2.

Very truly yours,

C. R. Dietz, General Manager  
Brunswick Steam Electric Plant

RMP/tt/LETDJ4

Enclosure

cc: Mr. R. C. DeYoung  
NRC Document Control Desk

OFFICIAL COPY

1022

8304110297 830401  
PDR ADOCK 05000325  
S PDR