

*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION

P.O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. B. RAY  
STATION MANAGER

March 25, 1983

RECEIVED  
NRC  
1983 MAR 31 PM 12:22  
SCE  
REGION V  
TELEPHONE  
(714) 492-7700

U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. R. H. Engelken, Regional Administrator

Dear Sir:

Subject: Docket No. 50-362  
Prompt Report  
Licensee Event Report 83-029  
San Onofre Nuclear Generating Station, Unit 3

Reference: Letter, H.B. Ray (SCE) to R.H. Engelken (NRC) Dated  
March 22, 1983


Pursuant to Section 6.9.1.12.1 of Appendix A Technical Specifications to Facility Operating License NPF-15 for San Onofre, Unit 3, this submittal provides the written confirmation of our March 25, 1983, prompt notification to the NRC of a reportable occurrence involving the High Pressure Safety Injection (HPSI) system.

The referenced letter provided you with confirmation of our prompt notification of a reportable occurrence involving the use of Westinghouse Electric Corporation gate valves in safety related systems. In that letter, we identified two (2) valves installed in the Unit 2 Component Cooling Water System. We have now identified one additional valve installed in the High Pressure Safety Injection (HPSI) system of Unit 3.

A 14-day follow-up report with a copy of Licensee Event Report (LER) No. 83-029 will be submitted by April 4, 1983, to address this event.

If there are any questions, please contact me.

Sincerely,



8304110300 830325  
PDR ADDCK 05000362  
S PDR

cc: A.E. Chaffee (USNRC Resident Inspector, Units 2 and 3)  
R.J. Pate (USNRC Resident Inspector, Units 2 and 3)

IE-22  
83-143