

LICENSEE EVENT REPORT

UPDATED REPORT

PREVIOUS REPORT DATE: 01-14-83

CONTROL BLOCK:

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M D C C N 1 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 57 CAT 58

7 8 14 15 25 26 30 57 CAT 58

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

REPORT

REPORT SOURCE: 01 L 6 0 5 0 0 0 3 1 7 7 1 2 1 5 8 2 8 0 3 2 4 8 3 9

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 0746 during normal operation, #11 containment cooling unit (CCU)
0 3 | tripped (T.S. 3.6.2.2). #12 Diesel generator (DG), the emergency power
0 4 | source for #14 4Kv bus and in turn #13 and #14 CCU's were out of service
0 5 | (T.S. 3.8.1.1). #21 DG was aligned to #14 4Kv bus and #13 and #14 CCU's
0 6 | were declared operable. At 1000 #11 CCU returned to service. At 1103,
0 7 | #21 DG was re-aligned to #24 4Kv bus restoring the minimum required A.C.
0 8 | power sources. Similar events: none.

SYSTEM CODE [0] [9] 7 8		CAUSE CODE [S] [B] (11) 9 10		CAUSE SUBCODE [X] (12) 11		COMPONENT CODE [Z] [Z] [Z] [Z] [Z] [Z] (14) 12 13 14 15 16 17 18						COMP. SUBCODE [Z] (15) 19		VALVE SUBCODE [Z] (16) 20			
(17) LER/RO REPORT NUMBER		EVENT YEAR [8] [2] 21 22		SEQUENTIAL REPORT NO. [—] 23		[0] [7] [5] 24 25 26		OCCURRENCE CODE [/] 27		[0] [3] 28 29		REPORT TYPE [X] 30		[—] 31		REVISION NO. [1] 32	
ACTION TAKEN [B] (18) 33		FUTURE ACTION [Z] (19) 34		EFFECT ON PLANT [Z] (20) 35		SHUTDOWN METHOD [Z] (21) 36		HOURS (22) [0] [0] [0] [0] 37 38 39 40		ATTACHMENT SUBMITTED [N] (23) 41		NPRD-4 FORM SUB. [N] (24) 42		PRIME COMP. SUPPLIER [Z] (25) 43		COMPONENT MANUFACTURER [Z] [9] [9] [9] (26) 44 45 46 47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Inspection of electrical connections at the motor terminal box showed

1 1 signs of one fast speed winding lead going to ground. Apparently, the

1 2 lead's taped connection had frayed from rubbing against the terminal box.

1 3 All fast speed winding leads were reterminated. Fast speed motor current

1 4 returned to normal. No further action is deemed necessary.

7								8						9											
FACILITY STATUS		% POWER						OTHER STATUS (30)						METHOD OF DISCOVERY						DISCOVERY DESCRIPTION (32)					
1	5	E	(28)	1	0	0	(29)	N/A	A	(31)	Operator Observation	(32)													

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)

1 6 2 33 10 34 N/A

45 N/A LOCATION OF RELEASE (36) 84

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	N/A	

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	0	0
0	0	0	40
		N/A	

8 9		11 12		
TYPE		DESCRIPTION		(43)
1	9	Z	(42)	N/A

7 8 9 10
 PUBLICITY (45) 8304110302 830324
 ISSUED DESCRIPTION PDR ADOCK 05000317 NRC USE ONLY
 2 0 N (44) N/A S PDR

NAME OF PREPARER M. A. Junge/L. F. Basso

PHONE: 301-269-4969/4933