

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

USNRC REGION II
ATLANTA, GEORGIA

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

March 10, 1983

TELEPHONE
83 MAR 21 AIO: 11 (204) 373-4531

Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

Subject: Oconee Nuclear Station
Docket Nos. 50-269, -270, -287


Dear Sir:

By letter dated February 25, 1983, the NRC issued IE Bulletin 83-01, Failure of Reactor Trip Breakers (Westinghouse DB-50) to open on Automatic Trip Signal. Duke has reviewed the Oconee plant design and has determined that the DB-50 breaker with an undervoltage trip attachment is not in use at Oconee.

In a followup action to the event at the Salem plant that caused the issuance of this bulletin, Duke, as well as other members of the B&W Owners Group, met with the NRC Task Force on March 8, 1983 to discuss with the Task Force the issues related to the event. As a result of this meeting, no further immediate actions were identified.

Duke will continue to evaluate the information from this event as it becomes available and will take any actions deemed necessary.

Very truly yours,



Hal B. Tucker

RLG/php

cc: Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. J. C. Bryant
NRC Resident Inspector
Oconee Nuclear Station

Mr. E. L. Conner, Jr.
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8304110317 830310
PDR ADOCK 05000269
Q PDR

IE11