



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

March 30, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Update Report - Fire Seal and
Secondary Containment Open
Penetrations
LER 82-027/99 X-2
AECM-83/0169

This letter submits an update to previous reports submitted on August 25, 1982, and December 14, 1982. The event for which the reports were submitted occurred on July 27, 1982, when it was determined that a fire rated seal was not installed in a spare HVAC penetration to the containment exhaust filter train room and that an open penetration existed in the secondary containment. The event was reported pursuant to Technical Specification 6.9.1.13.b.

The open penetration in the secondary containment has been sealed. A Design Change Package has been issued to seal the HVAC penetration. A final report will be submitted when the task is completed. Attached is LER 82-027/99 X-2, which is an interim report.

Yours truly,


FOR J. P. McGaughy, Jr.

JPM:sap
Attachment

cc: (See Next Page)

OFFICIAL COPY

8304110391 830330
PDR ADOCK 05000416
S PDR

IG 22

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0169

Page 2

cc: Mr. J. B. Richard (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555