

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	S	G	G	S	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	14								15	25										26	30					57	CAT	58
LICENSEE CODE		LICENSE NUMBER										LICENSE TYPE																	

CONT

REPORT
SOURCE

L	6	0	5	0	0	0	4	1	6	7	0	7	2	7	8	2	8	0	3	3	0	8	3	9
60	61	DOCKET NUMBER						68	69	EVENT DATE						74	75	REPORT DATE						80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[0] [2] On 7/27/82, during a special inspection it was discovered that seal AV-
[0] [3] 18D was not installed in a spare HVAC penetration to the containment ex-
[0] [4] haust filter train room. An LCO was entered in accordance with T.S.3.7.7.
[0] [5] Also, an open penetration in the secondary containment on the 177 feet
[0] [6] elevation was found. An LCO was entered due to failure to meet T.S.4.6.
[0] [7] 6.1.a.3. The event is reported pursuant to T.S.6.9 1.13.b. An update
[0] [8] will be submitted by May 20, 1983.

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22
		X	X	E		C		Z	Z	Z	Z	Z	Z	Z	Z
LER NO. REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.					
23	24	25	26	27	28	29	30	31	32	33	34				
17		8	2		0	2	7	/	9	9	X		2		
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER	
35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50
X		X		Z		Z		0	0	0	N	N		Z	
18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The open secondary containment penetration was sealed with a threaded
11 conduit plug. The HVAC penetration was not sealed because the current
12 drawings did not require it to be sealed. A design change package has
13 been issued to seal the HVAC penetration. In the interim, an hourly
14 firewatch is being maintained.

8 9
FACILITY STATUS
1 5 8 28
2 8 9
% POWER
0 0 0 29
10 11 12 13
OTHER STATUS (30) NA
METHOD OF DISCOVERY
C 31 Special Test
44 45 46
DISCOVERY DESCRIPTION (32)

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 7 33 10 34 NA

2 8 9 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES

NUMBER			TYPE	DESCRIPTION
1	7	0 0 0	37 Z 38	NA 39

PERSONNEL INJURIES	
NUMBER	DESCRIPTION (41)
000	NA

8304110399 830330

LOSS OF OR DAMAGE TO FACILITY		PDR ADOCK 05000416	
TYPE	DESCRIPTION	S	PDR
1 3	2 42 NA		

8 9 10
PUBLICATION
ISSUED DESCRIPTION (45)
[2] [0] [N] [44] NA _____ NRC USE ONLY

NAME OF PREPARER M. Scott Freeman and Boyd Shingleton PHONE

PHONE

NRC USE ONLY

1-800-851-7928