



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

March 23, 1983

Mr. R.C. Haynes
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-041/03L-0
ER 100450 FILE 841-23
PLA- 1592

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 83-041/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.C, in that the Division I Radiation Monitors for the Railroad Bay, Refuel Floor Wall Exhaust and Refuel Floor High Exhaust would not initiate Reactor Building Zone III Isolation and start the Standby Gas Treatment System.

H. W. Keiser
Superintendent of Plant-Susquehanna

JTT/dlf

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8304110436 830323
PDR ADOCK 05000387
S PDR

IE12