

Duke Power Company  
Oconee Nuclear Site  
P.O. Box 1439  
Seneca, SC 29679

J. W. HAMPTON  
Vice President  
(803)885-3499 Office  
(803)885-3564 Fax



**DUKE POWER**

September 8, 1994

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

Subject: Oconee Nuclear Station, Units 1, 2 and 3  
Docket Nos. 50-269, -270, -287  
Secondary System Decay Heat Removal  
Proposed Technical Specification  
Technical Specification 3.4

This letter is a supplement to the request for license amendment submitted in our letter dated December 8, 1993. This supplement is submitted in response to a telephone conversation on September 6, 1994 in which Mr. Len Wiens, NRC Project Manager, requested additional information regarding surveillance testing of the Emergency Condenser Circulating Water (ECCW) System suction supply to the Low Pressure Service Water (LPSW) System.

As discussed in our April 20, 1994 supplement to the proposed amendment, the ECCW System "first siphon" is required to provide flow to the LPSW pumps during a loss of off-site power (LOOP) event until forced flow can be reestablished. This mode of operation is tested during each refueling outage during the LPSW System Flow Test, Procedure No. PT/1,2 or 3/A/0251/23. We will continue to test the ECCW System siphon supply to the LPSW System on a refueling frequency.

Please contact David Patterson, Oconee Regulatory Compliance, (803) 885-3297 if there are any questions.

Very truly yours,

*J. W. Hampton*  
for J. W. Hampton

cc: L. A. Wiens, ONRR

S. D. Ebnetter  
Regional Administrator, Region II

P. E. Harmon  
Senior Resident Inspector

9409190090 940908  
PDR ADDCK 05000269  
P PDR

*Accol*  
*1/0*