



ENTERGY

Entergy Operations, Inc.

P.O. Box 8
Kilona, LA 70066
Tel 504 739 6774

R. F. Burski

Director
Nuclear Safety
Waterford 3

W3F1-94-0157

A4.05

PR

September 14, 1994

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Subject: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
Monthly Operating Report

Gentlemen:

Attached is the subject monthly report which covers the operating statistics for the month of August, 1994. This report is submitted per Section 6.9.1.6 of the Waterford 3 Technical Specifications for Facility Operating License No. NPF-38.

Very truly yours,

R.F. Burski
Director
Nuclear Safety

RFB/DFL/ssf
Attachment

cc: L.J. Callan (NRC Region IV)
R.B. McGehee
N.S. Reynolds
F. Yost (Utility Data Institute, Inc.)
J.T. Wheelock (INPO Records Center)
NRC Resident Inspectors Office

9409190136 940831
PDR ADDCK 05000382
R PDR

JE24

NRC MONTHLY OPERATING REPORT

SUMMARY OF OPERATIONS

WATERFORD 3

AUGUST 1994

The unit operated at an average reactor power of 99.7% and experienced no shutdowns or significant power reductions during the period.

PRESSURIZER SAFETY VALVE

FAILURES AND CHALLENGES

WATERFORD 3

During the month of August 1994, there were no pressurizer safety valve failures or challenges.

OPERATING DATA REPORT

DOCKET NUMBER: 50-382
UNIT NAME: WATERFORD 3
DATE OF REPORT: SEPTEMBER, 1994
COMPLETED BY: T.S. BECKER
TELEPHONE: 504-739-6683

OPERATING STATUS

1. Reporting Period: August, 1994
Gross Hours in Reporting Period: 744
2. Currently Authorized Power Level (MWt): 3390
Maximum Dependable Capacity (Net MWe): 1075
Design Electrical Rating (Net MWe): 1104
3. Power Level to which Restricted (if any) (Net MWe): N/A
4. Reasons for Restriction (if any): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. Number of Hours Reactor was Critical	<u>744.0</u>	<u>4,693.8</u>	<u>65,793.8</u>
6. Reactor Reserve Shutdown Hours	<u>-0-</u>	<u>-0-</u>	<u>-0-</u>
7. Hours Generator was On-line	<u>744.0</u>	<u>4,627.1</u>	<u>64,915.3</u>
8. Unit Reserve Shutdown Hours	<u>-0-</u>	<u>-0-</u>	<u>-0-</u>
9. Gross Thermal Energy Generated (MWH)	<u>2,514,659</u>	<u>15,397,374</u>	<u>214,425,851</u>
10. Gross Electrical Energy Generated (MWH)	<u>821,230</u>	<u>5,041,140</u>	<u>71,461,920</u>
11. Net Electrical Energy Generated (MWH)	<u>783,360</u>	<u>4,798,121</u>	<u>68,108,566</u>
12. Reactor Service Factor	<u>100.0</u>	<u>80.5</u>	<u>84.0</u>
13. Reactor Availability Factor	<u>100.0</u>	<u>80.5</u>	<u>84.0</u>
14. Unit Service Factor	<u>100.0</u>	<u>79.4</u>	<u>82.9</u>
15. Unit Availability Factor	<u>100.0</u>	<u>79.4</u>	<u>82.9</u>
16. Unit Capacity Factor (using MDC)	<u>97.9</u>	<u>76.5</u>	<u>80.9</u>
17. Unit Capacity Factor (Using DER)	<u>95.4</u>	<u>74.5</u>	<u>78.8</u>
18. Unit Forced Outage Rate	<u>0.0</u>	<u>0.7</u>	<u>3.3</u>

OPERATING DATA REPORT

DOCKET NUMBER: 50-382
UNIT NAME: WATERFORD 3
DATE OF REPORT: SEPTEMBER, 1994
COMPLETED BY: T.S. BECKER
TELEPHONE: 504-739-6683

OPERATING DATA REPORT (Con't)

19. Shutdowns Scheduled over next 6 Months (type, date and duration of each):

N/A

20. If Shutdown at end of report period, estimated date of startup:

21. Unit in Commercial Operation

	THIS MONTH	YR TO DATE	CUMULATIVE
22. Hours in Reporting Period	<u>744.0</u>	<u>5,831.0</u>	<u>78,336.0</u>
23. Unit Forced Outage Hours	<u>0.0</u>	<u>31.5</u>	<u>2,210.2</u>

24. Nameplate Rating (Gross MWe): 1200

25. If Changes Occur in Capacity Ratings (Items Number 2 and 24) Since Last Report,
Give Reasons: N/A

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NUMBER: 50-382
UNIT NAME: WATERFORD 3
DATE OF REPORT: SEPTEMBER, 1994
COMPLETED BY: T.S. BECKER
TELEPHONE: 504-739-6683

MONTH AUGUST, 1994

DAY AVERAGE DAILY POWER LEVEL
(MWe-NET)

1	<u>1058</u>
2	<u>1057</u>
3	<u>1058</u>
4	<u>1061</u>
5	<u>1060</u>
6	<u>1060</u>
7	<u>1059</u>
8	<u>1059</u>
9	<u>1059</u>
10	<u>1059</u>
11	<u>1058</u>
12	<u>1058</u>
13	<u>1057</u>
14	<u>1057</u>
15	<u>1056</u>
16	<u>1056</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-NET)

17	<u>1056</u>
18	<u>1056</u>
19	<u>1053</u>
20	<u>971</u>
21	<u>1051</u>
22	<u>1051</u>
23	<u>1048</u>
24	<u>1051</u>
25	<u>1054</u>
26	<u>1043</u>
27	<u>1055</u>
28	<u>1056</u>
29	<u>1056</u>
30	<u>1057</u>
31	<u>1053</u>

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NUMBER: 50-382
 UNIT NAME: WATERFORD 3
 DATE OF REPORT: SEPTEMBER 1994
 COMPLETED BY: T.S. BECKER
 TELEPHONE: 504-739-6683

REPORT FOR AUGUST, 1994

<u>Number</u>	<u>Date</u>	Type F = Forced S = Scheduled	Duration (Hours)	<u>Reason (1)</u>	Method of Shutting Down the Reactor or Reducing Power (2)	Cause, Comments and Corrective Actions
NONE						

(1) REASON

A = Equipment Failure (explain)
 B = Maintenance or Test
 C = Refueling
 D = Regulatory Restriction
 E = Operator Training and
 License Examination
 F = Administrative
 G = Operational Error (explain)
 H = Other (explain)

(2) METHOD

1 = Manual
 2 = Manual Scram
 3 = Automatic Scram
 4 = Continuation from Previous Period
 5 = Power Reduction
 6 = Other (explain)