

INDUSTRIAL PRETREATMENT  
QUARTERLY SELF-MONITORING RESULTS

Perry Nuclear Power Plant  
10 Center Rd.  
Perry, Ohio 44081

Permit No.: 1004911  
Report Date: 6/21/94  
Laboratory: Wadsworth/Alert

Date of Sample: 6/2 to 6/3/94  
Sample Location: Sewage Pump Station

Time of sample: 0900  
Name of Sampler: Greg Newman


Laboratory Address: 1401 Shuffel Dr.  
North Canton OH 44720

Date of Analysis: 6/3 to 6/14/94  
Flow: 33,000 gpd

Name of Analyst: Kathy Graves

PARAMETER	SAMPLE TYPE	EPA METHOD	ANALYSIS DATE	ANALYSIS RESULT
COD	Composite	410.4	6/9 to 6/10	240 mg/L
BOD	Composite	405.1	6/3 to 6/8	100 mg/L
TSS	Composite	160.2	6/7	140 mg/L
Silver	Composite	200.7	6/8 to 6/14	None Detected
pH	Grab	150.1	6/3	8.9 s.u.
Oil/Grease Gravimetric	Grab	413.1	6/9 to 6/10	10 mg/L

I certify under penalty of law that I have personally examined and I am familiar with the information in this report and that, based on my inquiry of those persons immediately responsible for obtaining the information contained in this report, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment.

  
Signature \_\_\_\_\_ Date 6/7/94 Title Vice President - Nuclear