

CONTROL BLOCK:

--	--	--	--	--	--

 ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	5	1	7	0	8	0	8	8	2	8	0	3	3	0	8	3	9
60	61									68	69					74	75							80
DOCKET NUMBER											EVENT DATE						REPORT DATE							

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) Valve testing the stroke time for hot leg

0 2 With the plant in Mode 3 during ISI valve testing, the stroke valve
0 3 sample isolation valve 2HV-0517 could not be measured due to simultaneous indication
0 4 of valve open and closed positions when valve was verified to be closed. Since the
0 5 valve was verified closed and the penetration was isolated by securing the redundant
0 6 valve in the closed position, there was no impact on health and safety of plant
0 7 personnel or the public.

0	8											80					
7	8	SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
0	9	S	D	D	Z	V	A	L	V	O	P	F	Z				
7	8	9	10	11	12	13	14	15	16	17	18	19	20				
LER RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
17	8	2	0	9	4	0	3	X	2								
21	22	23	24	26	27	28	29	30	31	32							
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
E	G	Z	Z	0	0	0	Y	N	A	Z	9	9	9				
18	19	20	21	22	23	24	25	26	27	28	29	30	31				

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)	
1 0	The cause of inoperability of 2HV-0517 was loosening of limit switch due to vibration.
1 1	The limit switch was adjusted and tightened. All station maintenance procedures dealing with setting of limit switches, torque switches and position indicators, after equipment maintenance, have been reviewed and appropriate revisions are currently being made to reflect individual valve characteristics. (See also
1 2	
1 3	
1 4	

7 8 9
FACILITY 82-103 and attachment)
STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY (32) DISCOVERY DESCRIPTION
1 5 B 78 0 0 0 29 NA B 31 Surveillance Testing
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)
1 6 Z 33 Z 34 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION (39)
1 7 0 0 0 37 Z 38 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
PERSONNEL INJURIES
NUMBER DESCRIPTION (41)
1 2 0 0 0 40 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION (43)
1 9 Z 42 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
PUBLICITY
ISSUED DESCRIPTION (45)
2 0 N 44 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50
NRC USE ONLY
8304110487 830330
PDR ADOCK 05000361
S PDR
714/102 7700

NAME OF PREPARER

NA
H. B. RAY

8304110487 830330
PDR ADDCK 05000361
S PDR

PHONE

NRC USE ONLY

714/492-7700