



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

March 24, 1983


Mr. R.C. Haynes
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 83-042/03L-0
ER 100450 FILE 841-23
PLA- 1595

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 83-042/03L-0. This event was determined to be reportable per Technical Specification 6.9.1.9.b, in that two channels of Primary Containment Atmosphere Gaseous Radioactivity Monitoring were inoperable at the same time.


H.W. Keiser
Superintendent of Plant-Susquehanna

JTT/cg

cc: Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G.G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8304110490 830324
PDR ADOCK 05000387
S PDR

TEW