



Entergy Operations, Inc.
River Bend Station
P.O. Box 220
St. Francisville, LA 70775

September 9, 1994

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington DC. 20555

Subject: Notification of Unusual Event
Reference: River Bend Station - Unit 1, Docket 50-458

File Nos.: G9.5, G9.25.1.4

RBG-40865

Gentlemen:

Please find attached a summary report of the "Notification of Unusual Event" (NOUE) which was declared at River Bend Station on September 8, 1994. The NOUE was declared based on Emergency Action Level 16. This summary report is submitted pursuant to Appendix 1 of NUREG-0654, Revision 1 and EAL Table 13.3-1 of the River Bend Station Emergency Plan.

Should you have any questions, please contact Mr. O. P. Bulich at (504) 336-6251.

Sincerely,

James J. Fisicaro
Director - Nuclear Safety

RMM
attachment

9409190171 940909
PDR ADOCK 05000458
S PDR

IF22
11

Notification of Unusual Event

September 9, 1994

RBG-40865

Page 2 of 2

U.S. NRC Regional Administrator, Region IV
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

NRC Senior Resident Inspector
P. O. Box 1051
St. Francisville, LA 70775

Col. William J. Croft
State of Louisiana
Office of Emergency Preparedness
P. O. Box 44217
Baton Rouge, LA 70804-4217

Mr. Jesse Means
Director of Emergency Management
West Feliciana Parish
P. O. Box 1877
St. Francisville, LA 70775

Mr. Charles J. LeBlanc
Director of Emergency Management
West Baton Rouge Parish
736 Eucalyptus Street
Port Allen, LA 70767

Mr. Oniel F. Leonard
Director of Emergency Management
Pointe Coupee Parish
P. O. Box 216
New Roads, LA 70760

Mr. Eddie Fuente
Mississippi State Board of Health
Division of Radiological Health
P. O. Box 1700
Jackson, MS 39205

Dr. L. Hall Bohlinger
Louisiana Radiation Protection Division
P. O. Box 82135
Baton Rouge, LA 70884-2135

Mr. Larry Gibbens
Director of Emergency Management
East Baton Rouge Parish
222 St. Louis Street
Baton Rouge, LA 70802

Mr. Travis W. Prewitt
Director of Emergency Management
East Feliciana Parish
P. O. Box 397
Clinton, LA 70722

Mr. James Maher
Director-Mississippi Emergency
Management Agency
P. O. Box 4501
Jackson, MS 39216

RIVER BEND STATION
NOTIFICATION OF UNUSUAL EVENT

On September 8, 1994 at approximately 2028 with the reactor at approximately 100% power (Mode 1), a reactor scram occurred.

At 2209, a Notification of Unusual Event (NOUE) was declared based on EIP-2-001, NOUE EAL 16. Plant conditions warranted increased awareness on the part of plant operating staff and a NOUE was declared at the discretion of the Shift Superintendent for potential augmentation of support organizations. The NOUE was subsequently terminated at 0030 September 9, 1994.

Initial notification to the States of Louisiana and Mississippi and the five local governments within the ten-mile Emergency Planning Zone was completed at 2215 and the Nuclear Regulatory Commission Incident Response Center was notified subsequent to the State and local governments but within one hour of the declaration. Notification of the event termination to the state and local governments and the NRC was completed at 0055 September 9, 1994.