NRC FORM 366 (12-81) 10 CFR 50

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

APPROVED BY OMB 3150-0011

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | PASES1 (2) | 00-00000-00 (3) | 41111 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T

01 REPORT SOURCE | L (6) | 05000387 (7) | 030483 (8) | 032883 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While making preparations to startup from hot shutdown, Zone III Reactor Building
03 normal ventilation fans tripped during the performance of an isolation system
04 surveillance test. The system would not restart and secondary containment, 0.25
05 inches of vacuum water gauge, could not be re-established. There were no con-
06 sequential effects to the public health and safety. The Standby Gas Treatment
07 System was available, but secondary containment was restored within 4 hours.
08

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
09	AA (11)	D (12)	Z (13)	ZZZZZZ (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	83	—	038	/	03	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER (26)
X (18)	G (19)	C (20)	Z (21)	0000	N (23)	N (24)	Z (25)	Z999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The method required to startup the Zone III ventilation is difficult to accomplish
11 and provides a good chance for the system to trip on high or low building differ-
12 ential pressure. The system engineer has reviewed the operating procedure and
13 submitted recommended changes to optimize the direction provided. The procedure
14 is currently being revised.

FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15 C (28)	000 (29)	n/a	L (31)	operator observation

ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16 Z (33)	Z (34)	n/a	n/a

PERSONNEL EXPOSURES NUMBER	TYPE	DESCRIPTION (39)
17 000 (37)	Z (38)	n/a

PERSONNEL INJURIES NUMBER	DESCRIPTION (41)
18 000 (40)	n/a

LOSS OF OR DAMAGE TO FACILITY TYPE	DESCRIPTION (43)
19 Z (42)	n/a

8304110576 830328
PDR ADOCK 05000387
S PDR

PUBLICITY ISSUED	DESCRIPTION (45)
20 N (44)	n/a

NRC USE ONLY

NAME OF PREPARER Jon T. Todd PHONE (717) 542-2181 X3524