

LICENSEE EVENT REPORT

CONTROL BLOCK

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D C C 2 2 0 0 - 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

01 REPORT SOURCE 00 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80
01 0 5 0 0 0 0 3 1 6 7 0 3 0 2 8 3 8 0 3 3 1 8 3 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 A SECURITY OFFICER WAS DISPATCHED TO CHECK CO DIESEL ROOM DOOR FOR SECURITY. THE
03 OFFICER DISCOVERED THE CO₂ SYSTEM ISOLATED WITH NO PERSONNEL IN ROOM. THIS WAS
04 NON-CONSERVATIVE WITH RESPECT TO T.S. 3.7.9.3. FIRE DETECTION SYSTEM (THERMISTORS)
05 REMAINED OPERABLE. THE HEALTH AND SAFETY OF THE PUBLIC WERE NOT AFFECTED.
06 PREVIOUS OCCURRENCES WERE REPORTED VIA 316/82-076, 315/82-037, 315/82-044,
07 315/82-045, 315/82-068, AND 316/82-054.

09 SYSTEM CODE 10 CAUSE CODE 11 CAUSE SUBCODE 12 COMPONENT CODE 13 COMP SUBCODE 14 VALVE SUBCODE 15
09 A B 11 A 12 A 13 I N S I T R U 14 S 15 7 16
17 LEAD REPORT NUMBER 18 EVENT YEAR 19 SEQUENTIAL REPORT NO. 20 OCCURRENCE CODE 21 REPORT TYPE 22 REVISION NO.
17 8 3 19 0 2 9 20 0 3 21 0
23 ACTION TAKEN 24 FUTURE ACTION 25 EFFECT ON PLANT 26 SHUTDOWN METHOD 27 HOURS 28 ATTACHMENT SUBMITTED 29 NPRD-4 FORM SUB. 30 PRIME COMP. SUPPLIER 31 COMPONENT MANUFACTURER
23 H 24 Z 25 Z 26 Z 27 0 0 0 0 28 N 29 N 30 N 31 C 1 2 5 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE RESPONSIBLE EQUIPMENT OPERATOR WAS CONTACTED AND THE SYSTEM WAS RETURNED TO
11 NORMAL. THE TWO OPERATORS HAVE BEEN REINSTRUCTED AS TO THE PROPER METHOD OF
12 ENTERING A CO₂ PROTECTED AREA. NO FURTHER ACTION PLANNED.

13
14

15 FACILITY STATUS 16 % POWER 17 OTHER STATUS 18 METHOD OF DISCOVERY 19 DISCOVERY DESCRIPTION 20
15 E 16 1 0 0 17 NA 18 B 19 SECURITY GUARD OBSERVATION

16 RELEASED OF RELEASE 17 AMOUNT OF ACTIVITY 18 LOCATION OF RELEASE 19
16 Z 17 NA 18 NA

17 PERSONNEL EXPOSURES 18 NUMBER 19 TYPE 20 DESCRIPTION 21
17 0 0 1 2 21 NA

18 PERSONNEL INJURIES 19 NUMBER 20 DESCRIPTION 21
18 0 0 1 2 21 NA

19 LOSS OF OR DAMAGE TO FACILITY 20 TYPE 21 DESCRIPTION 22
19 Z 22 NA

20 PUBLICITY 21 ISSUED DESCRIPTION 22
20 N 22 NA

NAME OF PREPARER D. E. KAUSE

PHONE (616) 465-5901

8304110709 830331
PDR ADDCK 05000316
S PDR