

LICENSEE EVENT REPORT

CONTROL BLOCK: _____

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	14						15	25										26	30				57	CAT	58			
		LICENSEE CODE						LICENSE NUMBER										LICENSE TYPE											

CON'T

REPORT SOURCE 7 8 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

0 1 L 6 0 5 0 0 0 3 1 6 7 0 3 0 4 8 3 8 0 3 3 1 8 3 9

DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | WHILE IN OPERATIONAL MODE 1, A UNIT SUPERVISOR ON A TOUR BEHIND THE CONTROL

0 3 | ROOM PANELS DISCOVERED A FLOOR PENETRATION F-6922 FIRE BARRIER SEAL IN A

0 4 | DEGRADED CONDITION, RENDERING IT NONFUNCTIONAL. A FIRE WATCH WAS IMMEDIATELY

0 5 | POSTED PURSUANT TO TECHNICAL SPECIFICATION 3.7.10. THE HEALTH AND SAFETY

0 6 | OF THE PUBLIC WERE NOT AFFECTED. PREVIOUS SIMILIAR EVENTS INCLUDE:

0 7 | 315/82-053, 315/82-055, 316/82-070, 316/82-103 AND 316/83-008.

0 8 |

7 8 9

SYSTEM CODE A B (11)		CAUSE CODE A (12)		CAUSE SUBCODE E (13)		COMPONENT CODE Z Z Z Z Z Z (14)				COMP. SUBCODE Z (15)		VALVE SUBCODE Z (16)	
LER/RO REPORT NUMBER 83 (17)		EVENT YEAR 83 (21)		SEQUENTIAL REPORT NO. 030 (24)		OCCURRENCE CODE 03 (28)		REPORT TYPE L (30)		REVISION NO. 0 (32)			
ACTION TAKEN H (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (22)		HOURS 0000 (22)		ATTACHMENT SUBMITTED N (23)		NPRD-4 FORM SUB. N (24)	
PRIME COMP. SUPPLIER Z (25)		COMPONENT MANUFACTURER Z 9 9 9 (26)											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE RESPONSIBLE INDIVIDUAL INTERPRETED THE WORDING OF THE PROCEDURE TO ALLOW ONE
1 1 HOUR FOR POSTING OF A FIRE WATCH. THE INDIVIDUAL WAS REPLACING TEMPORARY SEALS
1 2 WITH PERMANENT SEALS. AT LUNCH BREAK THE INDIVIDUAL LEFT THE OPEN PENETRATION
1 3 WITH ASSUMPTION HE HAD ONE HOUR TO RETURN OR POST A FIRE WATCH. THE RESPONSIBLE
1 4 INDIVIDUAL HAS BEEN RE-TRAINED.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	23	1	0	0	29	N/A	30
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		UNIT SUPERVISOR OBSERVATION		32	
1	6	Z	33	Z	34	N/A	35	N/A	36
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION		39	
1	7	0	0	0	37	Z	38	N/A	80
PERSONNEL INJURIES		NUMBER		DESCRIPTION				41	
1	8	0	0	0	40			N/A	80
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION				43	
1	9	Z	42			N/A			80
PUBLICITY		ISSUED		DESCRIPTION				45	
2	0	N	44			N/A			80
								8304110732 830331	
								PDR ADDCK 05000316	
								S PDR	
								NRC USE ONLY	

NAME OF PREPARER L.W. CASTLE

PHONE: (616) 465-5901