

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	2	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

REPORT  
SOURCE

REPORT SOURCE: 01 8  
DOCKET NUMBER: 60 61 0 5 0 0 0 3 1 6 7 88  
EVENT DATE: 69 0 3 0 4 8 3 74  
REPORT DATE: 75 0 3 3 1 8 3 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | DURING SURVEILLANCE TESTING ON THE MAIN TURBINE STOP VALVES ON 2-25-83, THE RESET  
0 3 | FUNCTION FOR THE PROXIMITY SWITCH ON STOP VALVE A, TRAIN A FAILED TO RESET IMMEDI-  
0 4 | ATELY. THE TRIP FUNCTION OF THE PROXIMITY SWITCH WAS VERIFIED TO OPERATE PROPERLY.  
0 5 | THE PROXIMITY SWITCH WAS MADE INOPERABLE FOR REPLACEMENT ON 3-4-83. THIS EVENT IS  
0 6 | NON-CONSERVATIVE WITH RESPECT TO TECHNICAL SPECIFICATION TABLE 3.3-1 ITEM 18.b. THE  
0 7 | ACTION REQUIREMENTS WERE MET. THE PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED.  
0 8 |  
7 8 9

SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE					
0	9	I	A	E	B	I	N	S	T	R	U	I	Z				
9	10	11	12	13	14	15	16	17	18	19	20	21	22				
EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.									
8	3	0	3	1	0	3	L	0									
21	22	23	24	25	26	27	28	29									
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
A	Z	Z	Z	0	0	0	0	0	N	Y	N	N	0	0	7		
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47			

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

1 0 THE ACTUAL CAUSE FOR THE SLUGGISH RESET FUNCTION ON THE PROXIMITY SWITCH COULD NOT BE  
1 1 DETERMINED, SINCE THIS TYPE OF SWITCH IS A POTTED SOLID STATE UNIT AND CANNOT BE  
1 2 DISASSEMBLED. THE PROXIMITY SWITCH MANUFACTURED BY NAMCO CONTROLS WAS REPLACED,  
1 3 VERIFIED TO BE OPERATING CORRECTLY AND RETURNED TO SERVICE. NO FURTHER ACTION IS  
1 4 PLANNED.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	28	1	0	0	29	NA	44
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	Z	34	NA	44	NA	45
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	0	37	Z	38	NA	44
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0	40	NA	44		
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	42	NA	44				
PUBLICITY		ISSUED		DESCRIPTION					
2	0	N	44	8304110742 830331	PDR	ADOCK 05000316	PDR	NRC USE ONLY	

NAME OF PREPARER R. A. PALMER

PHONE: 616-465-5901