



Commonwealth Edison

One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

April 5, 1983

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: LaSalle County Station Units 1 and 2
NUREG 0612 Control of Heavy Loads
Additional Information
NRC Docket Nos. 50-373 and 50-374

- References (a): E. D. Swartz letter to D. G. Eisenhower
dated June 22, 1981.
- (b): A. Schwencer letter to L. O. DelGeorge
dated July 2, 1982.
- (c): E. D. Swartz letter to D. G. Eisenhower
dated October 19, 1982.

Dear Sir:

References (a), (b), and (c) represent Commonwealth Edison Company's original Heavy Loads submittal, the draft Technical Evaluation Report (TER) by the NRC, and Commonwealth Edison Company's response to certain concerns in the draft TER.

On April 4, 1983, during a telecon with Dr. Bournia, et al, of your office, it was requested that Commonwealth Edison Company clarify its position regarding training, qualification, and conduct of crane operators. The purpose of this letter is to document that clarification, as follows:

LaSalle County Station will comply with ANSI B30.2-1976 with respect to crane operator training, qualification, and conduct.

13030

Director of NRR

- 2 -

April 5, 1983

If there are any further questions regarding this matter, please contact this office.

Enclosed for you use are one (1) signed original and forty (40) copies of this letter.

Very truly yours,

CW Schroeder 4/5/83

C. W. Schroeder
Nuclear Licensing Administrator

lm

cc: NRC Resident Inspector - LSCS

6255N