

Southern Nuclear Operating Company
Post Office Box 1295
Birmingham, Alabama 35201
Telephone (205) 868-5131



Dave Morey
Vice President
Farley Project

Southern Nuclear Operating Company
the southern electric system

September 13, 1994

Docket Nos. 50-348
50-364

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Joseph M. Farley Nuclear Plant
Monthly Operating Data Report

Gentlemen:


Attached are the August 1994 Monthly Operating Reports for Joseph M. Farley Nuclear Plant Units 1 and 2, as required by Section 6.9.1.10 of the Technical Specifications.

Also attached are corrected Unit 2 average daily power level pages from the May, June and July reports. An elevated value was erroneously calculated for the third day of each of these months. The program that calculates these averages was modified to account for the time change that occurred on April 3, 1994 (a 23 hour day), but it was not returned to a 24 hour day calculation for the subsequent months. Unit 1 was not affected.

The Unit 2 page for July 1994 has two additional corrections for the 26th and 27th of the month. These values were elevated because the Gross value was inadvertently switched with the Net value.

If you have any questions, please advise.

Respectfully submitted,


Dave Morey

RWC:jgp(mor)

Attachments

cc: Mr. S. D. Ebner
Mr. B. L. Siegel
Mr. T. M. Ross

94092002B7 940913
PDR ADDCK 0500034B
R PDR

JE24

Joseph M. Farley Nuclear Plant
Unit 1
Narrative Summary of Operations
August 1994

There were no unit shutdowns or major power reductions during the month.

The following safety related maintenance was conducted during the month:

1. Performed preventive maintenance and repairs on the 1-2A diesel generator. Included in the repairs were an intercooler heat exchanger leak and the overspeed trip device.