

Docket No. 50-423
B14972

Attachment 1

Millstone Nuclear Power Station, Unit No. 3
Proposed Revision to Technical Specifications

Main Steam Line Isolation Valve Closure Time
Marked-up Pages

September 1994

9409200301 940909
PDR ADOCK 05000423
P PDR

February 21, 1990

PLANT SYSTEMS

MAIN STEAM LINE ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.7.1.5 Each main steam line isolation valve (MSIV) shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

MODE 1:

With one MSIV inoperable but open, POWER OPERATION may continue provided the inoperable valve is restored to OPERABLE status within 4 hours; otherwise be in HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

MODES 2, 3, and 4:

With one MSIV inoperable, subsequent operation in MODE 2 or 3 or 4 may proceed provided the isolation valve is maintained closed. Otherwise, be in HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

10 4.7.1.5.1 Each MSIV shall be demonstrated OPERABLE by verifying full closure within 5 seconds in Modes 1, 2, and 3 when tested pursuant to Specification 4.0.5. The provisions of Specification 4.0.4 are not applicable for entry into MODE 3.

4.7.1.5.2 Each MSIV shall be demonstrated OPERABLE by verifying full closure within 120 seconds in Mode 4 when tested pursuant to Specification 4.0.5. The provisions of Specification 4.0.4 are not applicable for entry into Mode 3.

Docket No. 50-423
B14972

Attachment 2

Millstone Nuclear Power Station, Unit No. 3
Proposed Revision to Technical Specifications

Main Steam Line Isolation Valve Closure Time
Retyped Pages

September 1994

PLANT SYSTEMS

MAIN STEAM LINE ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.7.1.5 Each main steam line isolation valve (MSIV) shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTION:

MODE 1:

With one MSIV inoperable but open, POWER OPERATION may continue provided the inoperable valve is restored to OPERABLE status within 4 hours; otherwise be in HOT STANDBY within the next 6 hours and in HOT SHUTDOWN within the following 6 hours.

MODES 2, 3, and 4:

With one MSIV inoperable, subsequent operation in MODE 2 or 3 or 4 may proceed provided the isolation valve is maintained closed. Otherwise, be in HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.7.1.5 Each MSIV shall be demonstrated OPERABLE by verifying full closure within 10 seconds in Modes 1, 2, and 3 when tested pursuant to Specification 4.0.5. The provisions of Specification 4.0.4 are not applicable for entry into MODE 3.

4.7.1.5.2 Each MSIV shall be demonstrated OPERABLE by verifying full closure within 120 seconds in Mode 4 when tested pursuant to Specification 4.0.5. The provisions of Specification 4.0.4 are not applicable for entry into Mode 3.