

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004
(412) 393-5206
(412) 643-8069 FAX

GEORGE S. THOMAS
Division Vice President
Nuclear Services
Nuclear Power Division

September 13, 1994


U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

**Subject: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Use of the BioPak 240P Respirator During
Fire Fighting Activities
(TAC Nos. M82495 and M82496)**

By letter dated December 13, 1991, Duquesne Light Company requested authorization to use the BioPak 240P respirator to provide respiratory protection during fire fighting activities at Beaver Valley Power Station (BVPS), Units 1 and 2. By letter dated July 6, 1992, the NRC authorized the use of the BioPak 240P respirator contingent upon the prior modification of applicable plant procedures to require fire fighters to wear fire resistant head gear while using this respirator. This letter provides notification that applicable procedures have been revised to require the use of fire resistant head gear when the BioPak 240P respirator is used during fire fighting activities.

If there are any questions concerning this matter, please contact Mr. Doug Canan at (412) 393-7679.

Sincerely,


George S. Thomas

cc: Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. G. E. Edison, Sr. Project Manager

199000

A006
1/0

9409200347 940913
PDR ADDCK 05000334
F PDR