

CONTROL BLOCK: 

--	--	--	--	--	--

 ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	2	3	7	7	0	1	1	3	8	3	8	0	2	0	3	8	3	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing refuel surveillance DIS 2300-7, calibration check of the HPCI temper-  
0 3 ature switches, switch 2370A was found to trip at 204.7°F. Tech. Spec. limit of less  
0 4 than 200°F. (Table 3.2.1.) was exceeded. There was no effect to public health and  
0 5 safety. This event is of minimum safety significance since the remaining temperature  
0 6 switches were within Tech. Spec. limits and the Unit was shutdown. Last previous  
0 7 occurrence was reported by R.O. 82-8/03L-0 on Docket 50-249.

SYSTEM CODE S F		CAUSE CODE E		CAUSE SUBCODE E		COMPONENT CODE T N S T R U				COMP. SUBCODE S		VALVE SUBCODE Z	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 3				SEQUENTIAL REPORT NO. 0 0 9		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0	
ACTION TAKEN E	FUTURE ACTION Z	EFFECT ON PLANT Z	SHUTDOWN METHOD I Z		HOURS 0 0 0 0	ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. Y	PRIME COMP. SUPPLIER N		COMPONENT MANUFACTURER U 0 7 5		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cause of the event was due to switch set point drift. The setpoint was adjusted

1 1 according to DIS 2300-7 and repeatability verified. HPCI area temperature switches

1 2 will continue to be calibrated during each refueling outage.

FACILITY STATUS (1) 5 (H) (28) % POWER (0) (0) (0) (29) OTHER STATUS (30) N/A METHOD OF DISCOVERY (B) (31) DISCOVERY DESCRIPTION (32) Surveillance Tests  
 ACTIVITY CONTENT RELEASED OF RELEASE (1) 6 (Z) (33) (Z) (34) N/A AMOUNT OF ACTIVITY (35) N/A LOCATION OF RELEASE (36)  
 PERSONNEL EXPOSURES NUMBER (1) 7 (0) (0) (0) (37) TYPE (Z) (38) DESCRIPTION (39) N/A  
 PERSONNEL INJURIES NUMBER (1) 3 (0) (0) (0) (40) DESCRIPTION (41) N/A  
 LOSS OF OR DAMAGE TO FACILITY TYPE (1) 9 (Z) (42) DESCRIPTION (43) N/A  
 PUBLICITY ISSUED (2) (0) (N) (44) DESCRIPTION (45) N/A  
 8304110882 830203  
 PDR ADOCK 05000237  
 S PDR  
 NRC USE ONLY

NAME OF PREPARER A. Anandappa

PHONE: 815-942-2920, X-421