

LICENSEE EVENT REPORT

CAR 1426

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N Y R E G 1 2 0 0 - 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 L 6 0 5 0 0 0 2 4 4 7 0 2 2 4 8 3 8 0 3 2 5 8 3 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During the performance of PT-1, Periodic Test for the Rod Control System, the
0 3 reactor operator observed that the rod position indicator for control rod bank
0 4 "SD" Group 1 position C09 deviated from control bank "SD" by 12 steps. This event
0 5 made one rod position indicator for this bank inoperable. This is a violation
0 6 of Tech. Spec 3.10.5.2.
0 7
0 8

0 9 R B 11 E 12 E 13 I N S T R U 14 E 15 Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 8 3 — 0 1 0 — 0 3 L — 0
21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
E 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 N 25 M 0 3 5 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The plant I&C Group conducted an investigation and determined actual rod
1 1 position signal to be in agreement with bank position. The signal for the
1 2 rod position indicator was only in error and was adjusted to correct the
1 3 instrument drift.
1 4

1 5 E 28 1 0 0 29 N/A B 31 Operator Observation
7 8 9 10 12 13 44 45 46 80
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
1 6 Z 33 Z 34 N/A N/A
7 8 9 10 11 44 45 80
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
1 7 0 0 0 37 Z 38 N/A
7 8 9 11 12 13 80
PERSONNEL INJURIES NUMBER DESCRIPTION
1 8 0 0 0 40 N/A
7 8 9 11 12 80
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
1 9 Z 42 N/A
7 8 9 10 80
PUBLICITY ISSUED DESCRIPTION
2 0 N 44 N/A
7 8 9 10 80

8304110912 830325
PDR ADDCK 05000244
S PDR

NRC USE ONLY

NAME OF PREPARER E. Clair Edgar

PHONE: (315) 524-4446 ext. 248

80-7-926