



P.O. BOX 1000 CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN
VICE PRESIDENT
NUCLEAR

RECEIVED
APR 15 P5:29
PUBLIC DOCUMENT ROOM

April 1, 1983

Mr. James W. Keppler
Regional Administrator, Region III
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
Standby Diesel Generator ASME
Code Piping Welds [RDC 52(82)]

Dear Mr. Keppler:

This letter modifies our final report dated September 24, 1982, concerning Transamerica Delaval Standby Diesel Generator ASME Section III, Class 3 piping welds. Our interim report on this subject was submitted on April 28, 1982.

Due to the unanticipated complexity of the modification program undertaken to implement the repair and/or rework required per Nonconformance Report P039-0477, a small portion of this activity has not yet been completed. After re-evaluation of the remaining activities and review of the progress made to date, we now estimate that completion of corrective action to resolve Nonconformance Report P039-0477 will be by July 1, 1983.

Please call if there are additional questions.

Sincerely,

Cyril M. Shuster for

Murray R. Edelman
Vice President
Nuclear Group

8304110944 830401
PDR ADDOCK 05000440
S PDR

MRE:pab

cc: Mr. M. L. Gildner
NRC Site Office

Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, D.C. 20555

Records Center, SEE-IN
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

APR 4 1983

IE27