



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
P.O. BOX 97
PERRY, OHIO 44081

Robert A. Stratman
VICE PRESIDENT - NUCLEAR

September 14, 1994
PY-CEI/OEPA-207L

Ohio EPA
P.O. Box 163669
Columbus, Ohio 43216-3369

Gentlemen,

Enclosed is a revised Report Form 4500 for outfall 3IB00016004.
All the monitoring results for free available chlorine were not
included in calculations performed for the original submittal.

If you have any questions or require additional information,
please contact Donna Tizzano at (216)280-5514.

Very Truly Yours,

RAS:DGT:sc

Enclosure

9409210339 940914
PDR ADOCK 05000440
PDR

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

JE23

DAILY REPORT FORM

CLEVELAND ELECTRIC ILLUM CO 3IB00016004 AUG 1994
 NUCLEAR GROUP
 C/O PERRY NUCLEAR POWER PLANT
 10 CENTER ROAD ROOM E210
 NORTH PERRY 44081 LAKE

1 1

OHIO
63461

004 POINT REP OF DISCHARGE PRIOR TO
 ENTRY TO TUNNEL

FORM

CEI. PERRY

J.J. GRIMM

1
9991
9993
13
1

WATER
TEMP
F.

CONDUIT
FLOW
MGD

CHLOR
FREE A
MG/L

PH
S.U.

00011 50050 50064 00400

31	78	111.7	0.00	
32	78	124.3	0.00	8.1
33	78	129.0	0.00	
34	78	124.0	0.00	
35	76	131.6	0.00	8.1
36	73	139.7	0.00	
37	73	134.2	0.00	
38	74	132.4	0.00	8.0
39	74	121.1	0.09	
40	74	119.6	0.14	
41	73	128.2	0.06	
42	74	133.3	0.00	8.0
43	74	113.4	0.00	
44	75	116.2	0.00	
45	72	105.1	0.00	
46	74	105.9	0.00	8.1
47	74	106.8	0.00	
48	74	93.0	0.00	
49	75	92.9	0.00	8.1
50	76	89.1	0.00	
51	76	101.9	0.00	
52	77	91.8	0.00	
53	77	88.0	0.00	8.1
54	78	86.1	0.00	
55	79	80.9	0.00	
56	80	82.3	0.00	8.2
57	79	85.0	0.00	
58	82	82.3	0.00	
59	79	82.5	0.00	
60	79	83.9	0.00	8.1
61	79	91.0	0.00	

2362 3307.2 0.29 72.8
 76 106.7 0.01 8.1
 82 139.7 0.14 8.2
 72 80.9 0.00 8.0

NEITHER CHLORINE CONCENTRATION LIMITS. NOR CHLORINATION TIME LIMITS
 WERE EXCEEDED BETWEEN 8/9-8/11.

REPORTER

a/k/a

R. M. H.

117 A. L. 1