



Commonwealth Edison

Quad Cities Nuclear Power Station
22710 206 Avenue North
Cordova, Illinois 61242
Telephone 309/654-2241

NJK-83-123

April 4, 1983

J. Keppler, Regional Administrator
Office of Inspection and Enforcement
Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137


Reference: Quad-Cities Nuclear Power Station
Docket Number 50-265, DPR-30, Unit Two
Appendix A, Section 3.2.B, Table 3.2-2

Enclosed please find Reportable Occurrence Report Number RO 83-05/03L-0
for Quad-Cities Nuclear Power Station.

This report is submitted to you in accordance with the requirements of
Technical Specification 6.6.B.2.a; engineered safety feature instrument
setpoint found less conservative than Technical Specification limits,
but which does not affect the performance of the system's function.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION


N. J. Kalivianakis
Station Superintendent

NJK:DGC/bb

Enclosure

cc B. Rybak
N. Chrissotimos
INPO Records Center

APR 7 1983

8304120405 830404
PDR ADDCK 05000265
S PDR

IE 22