

[illegible]

REPORT SOURCE L 6 0 5 0 0 0 3 4 6 7 1 1 2 9 8 2 8 0 4 0 4 8 3 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

0 2 (NP-33-82-79) On 11/29/82 at 0920 hours, while performing ST 5074.01 on Component

0 3 Cooling Water (CCW) Train 1, operators discovered that CCl467, Decay Heat Cooler CCW

0 4 Outlet Valve would not open. Decay Heat Train 1 was declared inoperable, and the unit

0 5 entered the action statement of Technical Specification 3.5.2. There was no danger

0 6 to the health and safety of the public or station personnel. Decay Heat Train 2 was

0 7 operable and available to provide core cooling.

0	8	7	8	9											80							
SYSTEM CODE					CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE					COMP. SUBCODE		VALVE SUBCODE						
C	F	11	B	12	B	13	V	A	L	V	O	P	14	D	15	Z	16					
0		9	9	10	11	12	12	13	18					19	20							
17		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.												
LER/RO REPORT NUMBER	8	2	21	22	0	6	4	23	24	26	0	3	27	28	29	X	30	31	32			
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER						
A	18	X	19	Z	20	Z	21	0	0	0	0	Y	23	Y	24	N	25	H	0	3	5	26
33		34		35		36		37		40		41		42		43		44		47		
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)																						

1 0 The cause is manufacturing error. On 11/30/82 the valve actuator was inspected, and a

1 1 flanged bearing was found missing from the actuator mounting plate. CCl467 was placed

1 2 in the open position with the air isolated. Decay Heat Train 1 was declared operable

1 3 on 11/30/82 at 1145 hours, removing the unit from the action statement. On 12/15/82,

1 4 a flanged bearing was installed in CCl467 under Maintenance Work Order IC-661-82.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			
1	5	E	28	0	9	9	29	NA	B	31	During performance of ST 5074.01
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE					
1	6	Z	33	Z	34	NA		NA			
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	37	Z	38	NA			
PERSONNEL INJURIES		NUMBER		DESCRIPTION							
1	8	0	0	0	40	NA					
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION							
1		Z	42	NA							
PUBLICITY		ISSUED		DESCRIPTION							
2	0	N	44	NA							

8304120478 830404
PDR ADOCK 05000346
S PDR

NRC USE ONLY

NAME OF PREPARER Tom Isley

PHONE: 419-259-5000, Ext. 230