



C. Lance Terry  
Group Vice President

Log # TXX-94131  
File # 916 (3/4.8)  
916 (3/4.3) clo  
916 (3/4.5) clo  
916 (3/4.6) clo  
916 (3/4.7) clo  
10010  
Ref. # 10CFR50.90  
10CFR50.36

September 19, 1994

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

SUBJECT: ICHE PEAK STEAM ELECTRIC STATION (CPSES)  
- KET NOS. 50-445 AND 50-446  
SUBMITTAL OF LICENSE AMENDMENT REQUEST 94-015  
ONE-TIME EXTENSION OF EMERGENCY DIESEL GENERATOR  
AND RELATED SURVEILLANCE TESTING FROM 18 TO 24 MONTHS

Gentlemen:

Pursuant to 10CFR50.90, TU Electric hereby requests an amendment to the CPSES Unit 1 Facility Operating Licensing (NPF-87) and CPSES Unit 2 Facility Operating License (NPF-89) by incorporating the attached change into the CPSES Units 1 and 2 Technical Specifications. These changes apply to CPSES Unit 2 only.

Technical Specification Surveillance Requirement 4.8.1.1.2f requires that the Emergency Diesel Generators be tested on an 18 month basis. The requested change modifies the CPSES Technical Specifications to allow a one-time extension of six months for these EDG and other related 18-month Surveillance Requirements (SR).

Attachment 1 is the required affidavit. Attachment 2 provides a detailed description of the proposed change, a safety analysis of the change and TU Electric's determination that the proposed change does not involve a significant hazard consideration. Attachment 3 provides the affected Technical Specification pages, marked up to reflect the proposed change.

In accordance with 10CFR50.91(b), TU Electric is providing the State of Texas with a copy of this requested amendment.

220024

9409220165 940919  
PDR ADOCK 05000445  
P PDR

400 N. Olive L.B. 81 Dallas, Texas 75201

ADD

Some of the SR addressed by this license amendment request will become overdue in early 1996 without the requested interval extension. To avoid an unnecessary shutdown to perform the SR, TU Electric requests approval as quickly as reasonably possible but no later than November 1, 1994. Upon NRC approval of the requested changes, TU Electric requests a 30 day implementation period following the date of license amendment issuance.

Should you have any questions regarding the requested amendment, please contact Mr. Alan Quam at (817) 897-8621 or Mr. Manu Patel at (214) 812-8298.

Sincerely,

  
C. L. Terry

ADQ:tg

Attachments:      1.    Affidavit  
                      2.    Description and Assessment  
                      3.    Affected Technical Specification pages (NUREG-1468) as revised

cc:   Mr. L. J. Callan, Region IV  
      Ms. M. A. Miller, Region IV  
      Mr. T. A. Bergman, NRR  
      Resident Inspectors, CPSES

Mr. D. K. Lacker  
Bureau of Radiation Control  
Texas Department of Public Health  
1110 west 49<sup>th</sup> Street  
Austin, Texas 78704