



Consumers
Power
Company

General Offices: 212 West Michigan Avenue, Jackson, MI 49201 • (517) 788-0550

April 4, 1983

Dennis M Crutchfield, Chief
Operating Reactor Branch No 5
Nuclear Reactor Regulation
US Nuclear Regulatory Commission
Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - CORRECTION TO CONSUMERS POWER COMPANY RESPONSE TO
IE BULLETIN 82-02

Consumers Power Company's letter entitled "Response to IE Bulletin 82-02 Action Items 2 and 4.C," dated November 1, 1982, contained incorrect information. That letter stated that eight (8) studs from incore instrument flanges No's 3, 5 and 7 were declared unuseable and were replaced. A subsequent inspection has shown that twelve (12) studs were replaced on the affected flanges and that 12, rather than 16 studs as stated in our letter, were reused.

David J VandeWalle
Nuclear Licensing Administrator

CC Administrator, Region III, USNRC
NRC Resident Inspector - Palisades

8304120512 830404
PDR ADDCK 05000255
G PDR

OC0383-0028A-NL02

APR 6 1983

IE 11

CONSUMERS POWER COMPANY

Palisades Plant
Docket 50-255 - License DPR-20

CORRECTION TO RESPONSE TO IE BULLETIN 82-02

At the request of the Commission and pursuant to the Atomic Energy Act of 1954 and the Energy Reorganization Act of 1974, as amended, and the Commission's Rules and Regulations thereunder, Consumers Power Company submits our Correction to Consumers Power Company's Response to IE Bulletin 82-02 dated November 1, 1982, entitled "Response to IE Bulletin 82-02 Action Items 2 and 4.C." Consumers Power Company's response is dated April 4, 1983.

CONSUMERS POWER COMPANY

BY

R B DeWitt 74

R B DeWitt, Vice President
Nuclear Operations

Sworn and subscribed to before me this 4th day of April 1983.

Helen I. Dempski

Helen I Dempski, Notary Public
Jackson County, Michigan

My commission expires December 14, 1983.