

INSTRUMENTATION

3/4.3.3 MONITORING INSTRUMENTATION

RADIATION MONITORING FOR PLANT OPERATIONS

LIMITING CONDITION FOR OPERATION

3.3.3.1 The radiation monitoring instrumentation channels for plant operations shown in Table 3.3-6 shall be OPERABLE with their Alarm/Trip Setpoints within the specified limits.

APPLICABILITY: As shown in Table 3.3-6.

ACTION:

- a. With a radiation monitoring channel Alarm/Trip Setpoint for plant operations exceeding the value shown in Table 3.3-6, adjust the Setpoint to within the limit within 4 hours or declare the channel inoperable.
- b. With one or more radiation monitoring channels for plant operations inoperable, take the ACTION shown in Table 3.3-6.
- c. The provisions of Specification/ 3.0.3 and ~~3.0.4~~ are not applicable. 1

SURVEILLANCE REQUIREMENTS

4.3.3.1 Each radiation monitoring instrumentation channel for plant operations shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL CALIBRATION and DIGITAL CHANNEL OPERATIONAL TEST for the MODES and at the frequencies shown in Table 4.3-3.

Replace with revised bases

3/4.0 APPLICABILITY

BASES

The specifications of this section provide the general requirements applicable to each of the Limiting Conditions for an Operation and Surveillance Requirements within Section 3/4. In the event of a disagreement between the requirements stated in these Technical Specifications and those stated in an applicable Federal Regulation or Act, the requirements stated in the applicable Federal Regulation or Act shall take precedence and shall be met.

3.0.1 This specification defines the applicability of each specification in terms of defined OPERATIONAL MODES or other specified conditions and is provided to delineate specifically when each specification is applicable.

3.0.2 This specification defines those conditions necessary to constitute compliance with the terms of an individual Limiting Condition for Operation and associated ACTION requirement.

3.0.3 The specification delineates the measures to be taken for those circumstances not directly provided for in the ACTION statements and whose occurrence would violate the intent of a specification. For example, Specification 3.5.2 requires two independent ECCS subsystems to be OPERABLE and provides explicit ACTION requirements if one ECCS subsystem is inoperable. Under the requirements of Specification 3.0.3, if both the required ECCS subsystems are inoperable, within 1 hour measures must be initiated to place the unit in at least HOT STANDBY within the next 6 hours, and in at least HOT SHUTDOWN within the following 6 hours. As a further example, Specification 3.6.2.1 requires two Containment Spray Systems to be OPERABLE and provides explicit ACTION requirements if one Spray System is inoperable. Under the requirements of Specification 3.0.3 if both the required Containment Spray Systems are inoperable, within 1 hour measures must be initiated to place the unit in at least HOT STANDBY within the next 6 hours, in at least HOT SHUTDOWN within the following 6 hours, and in COLD SHUTDOWN within the subsequent 24 hours. It is acceptable to initiate and complete a reduction in OPERATIONAL MODES in a shorter time interval than required in the ACTION statement and to add the unused portion of this allowable out-of-service time to that provided for operation in subsequent lower OPERATIONAL MODE(S). Stated allowable out-of-service times are applicable regardless of the OPERATIONAL MODE(S) in which the inoperability is discovered but the times provided for achieving a mode reduction are not applicable if the inoperability is discovered in a mode lower than the applicable mode. For example, if the Containment Spray System was discovered to be inoperable while in STARTUP, the ACTION Statement would allow up to 156 hours to achieve COLD SHUTDOWN. If HOT STANDBY is attained in 16 hours rather than the allowed 78 hours, 140 hours would still be available before the plant would be required to be in COLD SHUTDOWN. However, if this system was discovered to be inoperable while in HOT STANDBY, the 6 hours provided to achieve HOT STANDBY would not be additive to the time available to achieve COLD SHUTDOWN so that the total allowable time is reduced from 156 hours to 150 hours.

3.0.4 This specification provides that entry into an OPERATIONAL MODE or other specified applicability condition must be made with: (1) the full complement of required systems, equipment, or components OPERABLE, and (2) all other parameters as specified in the Limiting Conditions for Operation being met without regard for allowable deviations and out-of-service provisions contained in the ACTION statements.