

Mailing Address
Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 783-6081

F. L. Clayton, Jr.
Senior Vice President
Flintridge Building



April 6, 1983

Docket Nos. 50-348
50-364

Director, Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. S. A. Varga

Joseph M. Farley Nuclear Plant - Units 1 and 2
Multi-Plant Action Item B-32, Administrative Technical
Specification Change

Gentlemen:

At the request of the NRC Staff, Alabama Power Company has reviewed a discrepancy between Technical Specification Table 3.3-3, Item 1.e., and FSAR Figure 7.3-1, Sheet 3, to determine if a bypass provision exists for the "differential pressure between steam lines - high" signal for safety injection actuation. The conclusion is that the FSAR is correct in showing no bypass provisions for this safety injection signal. The Technical Specification footnote indicating such a bypass is an administrative error.

Alabama Power Company hereby requests an administrative change to delete the incorrect footnote reference shown on Item 1.e. of Table 3.3-3 in the Farley Nuclear Plant Technical Specifications. This proposed change has been reviewed by the Plant Operations Review Committee. The proposed change to the Technical Specification pages is included as an attachment. The Nuclear Operation Review Committee will review this change at a future meeting.

This letter is a supplement to the Alabama Power Company letter dated November 16, 1982. The class of this proposed change is designated as Class II for Unit 1 and Class I for Unit 2 in accordance with 10 CFR 170.22 requirements. A check for \$1,600.00 to cover the total amount of fees required was enclosed with the November 16, 1982 letter. NRC approval is requested by September 1, 1983.

8304120627 830406
PDR ADOCK 05000348
PDR


Pool

Mr. S. A. Varga
U. S. Nuclear Regulatory Commission

April 6, 1983
Page 2

In accordance with 10 CFR 50.30 (c)(1)(i), three signed originals and forty (40) additional copies of this proposed change are enclosed.

Yours very truly,


F. L. Clayton Jr.


FLCJr/GGY:1sh-D18

Attachment

cc: Mr. R. A. Thomas
Mr. G. F. Trowbridge
Mr. J. P. O'Reilly
Mr. E. A. Reeves
Mr. W. H. Bradford

SWORN TO AND SUBSCRIBED BEFORE ME

THIS 6th DAY OF April, 1983



Notary Public

My Commission Expires: 1-10-87