ENCLOSURE 1

PROPOSED TECHNICAL SPECIFICATION CHANGES
BROWNS FERRY NUCLEAR PLANT UNITS 1, 2, AND 3
(TVA BFNP TS 176 SUPPLEMENT 4)

UNIT 1

TABLE 4.1.B

REACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENT CALIBRATION

MINIMUM CALIBRATION FREQUENCIES FOR REACTOR PROTECTION INSTRUMENT CHANNELS

Instrument Channel	Group (1)	Calibration	Minimum Frequency (2)
IRM High Flux	C	Comparison to APRM on Controlled startups (6)	Note (4)
APRM High Flux			
Output Signal	B	Heat Balance	Once every 7 days
Flow Bias Signal	B	Calibrate Flow Bias Signal (7)	Once/operating cycle
LPRM Signal	B	TIP System Traverse (8)	Every 1000 Effective Full Power Hours
High Reactor Pressure	A	Standard Pressure Source	Every 3 Months
High Drywell Pressure	A	Standard Pressure Source	Every 3 Months
Reactor Low Water Level	A	Pressure Standard	Every 3 Months
High Water Level in Scram Discharge Volume		Note (5)	Note (5)
Turbine Condenser Low Vacuum	A	Standard Vacuum Source	Every 3 Months
Main Steam Line Isolation Valve Closure	A	Note (5)	Note (5)
Main Steam Line High Radiation	B	Standard Current Source (3)	Every 3 Months
Turbine First Stage Pressure Permissive	A	Standard Pressure Source	Every 6 Months
Turbine Cont. Valve Fast Closure or Turbine Trip	A	Standard Pressure Source	Once/operating cycle
Turbine Stop Valve Closure	A	Note (5)	Note (5)

modes. In the power range the APRM system provides required protection. Ref. Section 7.5.7 FSAR. Thus, the IRM System is not required in the Run mode. The APRM's and the IRM's provide adequate coverage in the startup and intermediate range.

The high reactor pressure, high drywell pressure, reactor low water level and scram discharge volume high level scrams are required for Startup and Run modes of plant operation. They are, therefore, required to be operational for these modes of reactor operation.

The requirement to have the scram functions as indicated in Table 3.1.1 operable in the Refuel mode is to assure that shifting to the Refuel mode during reactor power operation does not diminish the need for the reactor protection system.

The turbine condenser low vacuum scram is only required during power operation and must be bypassed to start up the unit. Below 154 psig turbine first stage pressure (30% of rated), the scram signal due to turbine stop valve closure, and turbine control valve fast closure or turbine trip is bypassed because flux and pressure scram are adequate to protect the reactor.

Because of the APRM downscale limit of $\geq$ 3% when in the Run mode and high level limit of $\leq$ 15% when in the Startup Mode, the transition between the Startup and Run Modes must be made with the APRM instrumentation indicating between 3% and 15% of rated power or a control rod scram will occur. In addition, the IRM system must be indicating below the High Flux setting (120/125 of scale) or a scram will occur when in the Startup Mode. For normal operating conditions, these limits provide assurance of overlap between the IRM system and APRM system so that there are no "gaps" in the power level indications (i.e., the power level is continuously monitored from beginning of startup to full power and from full power to shutdown). When power is being reduced, if a transfer to the Startup mode is made and the IRM's have not been fully inserted (a maloperational but not impossible condition) a control rod block immediately occurs so that reactivity insertion by control rod withdrawal cannot occur.

UNIT 2

TABLE 4.1.B
REACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENT CALIBRATION
MINIMUM CALIBRATION FREQUENCIES FOR REACTOR PROTECTION INSTRUMENT CHANNELS

Instrument Channel	Group (1)	Calibration	Minimum Frequency (2)
IRM High Flux	C	Comparison to APRM on Controlled startups (6)	Note (4)
APRM High Flux			
Output Signal	B	Heat Balance	Once every 7 days
Flow Bias Signal	B	Calibrate Flow Bias Signal (7)	Once/operating cycle
LPRM Signal	B	TIP System Traverse (8)	Every 1000 Effective Full Power Hours
High Reactor Pressure	A	Standard Pressure Source	Every 3 Months
High Drywell Pressure	A	Standard Pressure Source	Every 3 Months
Reactor Low Water Level	A	Pressure Standard	Every 3 Months
High Water Level in Scram Discharge Volume	A	Note (5)	Note (5)
Turbine Condenser Low Vacuum	A	Standard Vacuum Source	Every 3 Months
Main Steam Line Isolation Valve Closure	A	Note (5)	Note (5)
Main Steam Line High Radiation	B	Standard Current Source (3)	Every 3 Months
Turbine First Stage Pressure Permissive	A	Standard Pressure Source	Every 6 Months
Turbine Cont. Valve Fast Closure or Turbine Trip	A	Standard Pressure Source	Once/operating cycle
Turbine Stop Valve Closure	A	Note (5)	Note (5)

modes. In the power range the APRM system provides required protection. Ref. Section 7.5.7 FSAR. Thus, the IRM System is not required in the Run mode. The APRM's and the IRM's provide adequate coverage in the startup and intermediate range.

The high reactor pressure, high drywell pressure, reactor low water level and scram discharge volume high level scrams are required for Startup and Run modes of plant operation. They are, therefore, required to be operational for these modes of reactor operation.

The requirement to have the scram functions as indicated in Table 3.1.1 operable in the Refuel mode is to assure that shifting to the Refuel mode during reactor power operation does not diminish the need for the reactor protection system.

The turbine condenser low vacuum scram is only required during power operation and must be bypassed to start up the unit. Below 154 psig turbine first stage pressure (30% of rated), the scram signal due to turbine stop valve closure, and turbine control valve fast closure, or turbine trip is bypassed because flux and pressure scram are adequate to protect the reactor.

Because of the APRM downscale limit of $\geq$ 3% when in the Run mode and high level limit of $\leq$ 15% when in the Startup Mode, the transition between the Startup and Run Modes must be made with the APRM instrumentation indicating between 3% and 15% of rated power or a control rod scram will occur. In addition, the IRM system must be indicating below the High Flux setting (120/125 of scale) or a scram will occur when in the Startup Mode. For normal operating conditions, these limits provide assurance of overlap between the IRM system and APRM system so that there are no "gaps" in the power level indications (i.e., the power level is continuously monitored from beginning of startup to full power and from full power to shutdown). When power is being reduced, if a transfer to the Startup mode is made and the IRM's have not been fully inserted (a maloperational but not impossible condition) a control rod block immediately occurs so that reactivity insertion by control rod withdrawal cannot occur.

UNIT 3

TABLE 4.1.B
REACTOR PROTECTION SYSTEM (SCRAM) INSTRUMENT CALIBRATION
MINIMUM CALIBRATION FREQUENCIES FOR REACTOR PROTECTION INSTRUMENT CHANNELS

Instrument Channel	Group (1)	Calibration	Minimum Frequency (2)
IRM High Flux	C	Comparison to APRM on Controlled startups (6)	Note (4)
APRM High Flux	B	Heat Balance	Once every 7 days
Output Signal	B	Calibrate Flow Bias Signal (7)	Once/operating cycle
Flow Bias Signal			
LPRM Signal	B	TIP System Traverse (8)	Every 1000 Effective Full Power Hours
High Reactor Pressure	A	Standard Pressure Source	Every 3 Months
High Drywell Pressure	A	Standard Pressure Source	Every 3 Months
Reactor Low Water Level	A	Pressure Standard	Every 3 Months
High Water Level in Scram Discharge Volume	A	Note (5)	Note (5)
Turbine Condenser Low Vacuum	A	Standard Vacuum Source	Every 3 Months
Main Steam Line Isolation Valve Closure	A	Note (5)	Note (5)
Main Steam Line High Radiation	B	Standard Current Source (3)	Every 3 Months
Turbine First Stage Pressure Permissive	A	Standard Pressure Source	Every 6 Months
Turbine Cont. Valve Fast Closure or Turbine Trip	A	Standard Pressure Source	Once/operating cycle
Turbine Stop Valve Closure	A	Note (5)	Note (5)

which a scram would be required but not be able to perform its function adequately.

A source range monitor (SRM) system is also provided to supply additional neutron level information during startup but has no scram functions. Ref. Section 7.5.4 FSAR. Thus, the IRM is required in the Refuel and Startup modes. In the power range the APRM system provides required protection. Ref. Section 7.5.7 FSAR. Thus, the IRM System is not required in the Run mode. The APRM's and the IRM's provide adequate coverage in the startup and intermediate range.

The high reactor pressure, high drywell pressure, reactor low water level and scram discharge volume high level scrams are required for Startup and Run modes of plant operation. They are, therefore, required to be operational for these modes of reactor operation.

The requirement to have the scram functions as indicated in Table 3.1.1 operable in the Refuel mode is to assure that shifting to the Refuel mode during reactor power operation does not diminish the need for the reactor protection system.

The turbine condenser low vacuum scram is only required during power operation and must be bypassed to start up the unit. Below 154 psig turbine first stage pressure (30% of rated), the scram signal due to turbine stop valve closure, and turbine control valve fast closure or turbine trip is bypassed because flux and pressure scram are adequate to protect the reactor.

Because of the APRM downscale limit of $\geq$ 3% when in the Run mode and high level limit of $\leq$ 15% when in the Startup Mode, the transition between the Startup and Run Modes must be made with the APRM instrumentation indicating between 3% and 15% of rated power or a control rod scram will occur. In addition, the IRM system must be indicating below the High Flux setting (120/125 of scale) or a scram will occur when in the Startup Mode. For normal operating conditions, these limits provide assurance of overlap between the IRM system and APRM system so that there are no "gaps" in the power level indications (i.e., the power level is continuously monitored from beginning of startup to full power and from full power to shutdown). When power is being reduced, if a transfer to the Startup mode is made and the IRM's have not been fully inserted (a maloperational but not impossible condition) a control rod block immediately occurs so that reactivity insertion by control rod withdrawal cannot occur.

ENCLOSURE 2

JUSTIFICATION AND EXPLANATION
TVA BFNP TS 176
SUPPLEMENT 4

Pages 40 and 44 (Units 1 and 2)
Pages 39 and 43 (Unit 3)

The proposed change is to add Instrument Channel "Turbine Control Valve Fast Closure or Turbine Trip" to Table 4.1.B, Reactor Protection System Instrument calibration frequencies. The technical specifications currently have this instrument channel in Table 3.1.A, RPS Instrumentation Requirement, and Table 4.1.A, RPS Instrumentation Functional Test Frequencies. This addition to Table 4.1.B is needed to make these tables on RPS instrumentation consistent.

By TVA application for license amendment TVA BFNP TS 162, Tables 3.1.A and 4.1.A were revised by combining trip functions "Turbine Control Valve Fast Closure" and "Turbine Control Valve - Loss of Control Oil Pressure" into one, entitled "Turbine Control Valve Fast Closure or Turbine Trip." This change was done for clarification only. The proposed change was approved and issued as amendment Nos. 85, 82, and 56 to Browns Ferry units 1, 2, and 3 licenses respectively, dated July 22, 1982. This change was addressed in the Safety Evaluation Report prepared in support of those license amendments. This change to Table 4.1.B was inadvertently not included in TVA submittal TS 162 but is needed for consistency. The changes to the table and Bases in this TS 176 Supplement 4 are for clarification only.