

# Duquesne Light Company

Beaver Valley Power Station  
PO Box 8  
Shippingport, PA 15077-0008

JOHN D. SIEBER  
Vice President - Nuclear Group

412/391-0266

April 12, 1991

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 2  
Docket No. 50-412, License No. NPP-73  
Proposed Operating License Change Request No. 52  
(TAC No. 30042)


Enclosed are the following items:

1. An application to amend the operating license for modification of Technical Specification 3.3.3.8 by eliminating expired action statement c and reducing the total number of channels specified for RVLIS.
2. Documents designated Attachments A, B and C which set forth, respectively, the change in Technical Specifications, safety analysis and no significant hazards evaluation, and typed replacement Technical Specification pages.

This proposed change was reviewed by the Onsite Safety Committee and Offsite Review Committee and was determined to be safe based on the attached safety analysis.

The requested target date for approval of this proposed change is November 29, 1991.

Sincerely,

  
J. D. Sieber  
Vice President  
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector  
Mr. T. T. Martin, NRC Region I Administrator  
Mr. A. W. DeAgazio, Project Manager  
Mr. T. M. Gerusky, Director BRP/DER  
Mr. R. Janati, BRP/DER  
Mr. R. Saunders (VEPCO)

9104250242 910412  
PDR ADOCK 05000412  
PDR

ADD1