



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 8, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-015/0 - Fire
Rated Penetrations Found
Open
AECM-83/0223

On March 11, 1983, during a special inspection of fire-rated assemblies, three open penetrations were identified. A firewatch was established in accordance with Technical Specification 3.7.7 Action (a).

The following penetrations were identified as being open; 1) CE-215D - a four inch opening between the Lower Cable Spreading Room and Computer Room in the Control Building, 2) an opening (not identified on drawings) from the Lower Cable Spreading Room to an HVAC chase, and 3) an opening (not identified on penetration drawings) to the Auxiliary Building Stairwell at elevation 139 feet.

Material Nonconformance Reports (MNCR's) 83-213, 83-214, and 83-215 were issued to initiate corrective action. The deficiencies are attributed to construction error. The estimated restoration date is May 30, 1983. This is a Special Report submitted pursuant to Technical Specification 6.9.2.

Yours truly,

J. P. McGaughy, Jr.
FOR J. P. McGaughy, JR.

JPM:sap

cc: (See Next Page)

8304130276 830408
PDR ADQCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

1022

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0223

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McCeehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555