



State of New Jersey
Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625-0415
Tel (609) 987-2032
Fax (609) 987-6354

September 15, 1994

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Hope Creek Generating Station
Docket No. 50-354
License Change Request LCR 94-16
Emergency Diesel Generator (EDG) Fuel Oil
Surveillance Requirements

On July 28, 1994, Public Service Electric and Gas Company submitted the subject license change request to the Nuclear Regulatory Commission. This request would revise Technical Specification Section 3/4.8.1 "AC Sources." The revised specification removes the surveillance requirements, methodology and frequency for EDG fuel oil from the Technical Specification and relocates them in a controlled procedure (VSH.SS-CA.ZZ-0013(Q)).

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering reviewed the above amendment in accordance with the requirements of 10CFR50.91(b), and has no comments.

If you have any questions, please contact Suren Singh at (609) 987-2039 or Rich Pinney at (609) 987-2086.

Sincerely,

Kent Tosch, Manager
Bureau of Nuclear Engineering

230041

9409260216 940915
PDR ADDCK 05000354
PDR

New Jersey is an Equal Opportunity Employer
Recycled Paper

JE25 1/0

c: Assistant Director Lipc i
Radiation Protection Programs
N.J. DEP

Dave Moran
Acting NRC Project Manager

D. Chawaga
NRC Region I State Liaison

C. Marschall
Artificial Island Senior Resident Inspector

F. Thomson
Manager, Licensing and Regulation
PSE&G