



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 7, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-013/0 - Fire
Doors Blocked Open for
Planned Maintenance
Activity
AECM-83/0208

On March 1, 1983, and March 3, 1983, fire doors 1A109 (Elevation 93 feet, Auxiliary Building) and OC709 and OC710 (Upper Cable Spreading Room, Control Building) were blocked open to perform planned maintenance activities. Door 1A109 was opened to permit the routing of a supply hose for a hydrostatic test. Doors OC709 and OC710 were opened to route welding leads for a planned maintenance activity. Hourly firewatches are being conducted and will be maintained for the duration of the Limiting Condition for Operation in accordance with Technical Specification 3.7.7.

The fire doors will be closed and secured upon completion of the related work tasks. The estimated completion date for the work is April 25, 1983. This is submitted as a Special Report pursuant to Technical Specification 6.9.2.

Yours truly,


FOR J. P. McGaughy, JR

JPM:sap

cc: (See Next Page)

8304130372 830407
PDR ADDCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY
II 22

83 APR 11 AG: 50

US NRC REGION II
ATLANTA, GEORGIA

MISSISSIPPI POWER & LIGHT COMPANY

AECM-83/0208

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555