LICENSEE EVENT REPORT

BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | TNSNP1 (2) | 00-00000-00 (3) | 4 (4) | 1111 | [ ] (5)

7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

01 | REPORT SOURCE [L] (6) | 05000327 (7) | 031183 (8) | 040683 (9)

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Unit 1 in mode 1 at 100% Rx power with the RCS temperature and pressure at 578

03 | degrees F and 2240 psig. While running a shortened interval of surveillance

04 | instruction (SI) 196 as committed to in SQRO-50-327/82135 R1, it was discovered

05 | that three of four level switches were out of tolerance. There was no effect

06 | upon public health and safety. Previous occurrences - six (SQRO-50-327/82135,

07 | 83002, 83022, and SQRO-50-328/82137, 83013, 83023).

08 |

7 8 9 80

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
SF (11)	E (12)	E (13)	INSTRU (14)	S (15)	Z (16)
9 10	11	12	13 18	19	20

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8	3	—	041	/	03	L	—	0
	21 22		23	24 26	27	28 29	30	31	32

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E (18)	E (19)	Z (20)	Z (21)	0000	N (23)	N (24)	N (25)	I204
33	34	35	36	37 40	41	42	43	44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | 1-LS-87-21, -23, and -24 were out of tolerance as specified in surveillance

11 | requirement 4.5.1.2.C.1. The probable causes are instrument drift, calibration

12 | techniques, and testing techniques. The switches were recalibrated and returned

13 | to service. All four level switches will be rechecked in 30 days per TVA's

14 | previous commitment. A revised setpoint and tolerance has been submitted to NRC.

7 8 9 80

15 | FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance test

7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

7 8 9 10 11 44 45 80

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

7 8 9 11 12 13 80

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

7 8 9 11 12 80

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

7 8 9 10 80

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA

7 8 9 10 68 69 80

8304130375 830406
PDR ADOCK 05000327
S PDR

NRC USE ONLY

Name of Preparer: W. C. Ludwig /M. R. Harding Phone: (615) 870-6422