NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NCBEP2 (2) | 00-00000-00 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 - 0 3 2 4 (7) | 0 3 1 5 8 3 (8) | 0 4 0 5 8 3 (9)
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During plant operation, performance of High Steam Line Radiation Channel Functional
03 Test, PT-1.1.12PC, revealed main steam line radiation monitor 2-D12-LRM-K603A was
04 actuating at 4.35 (versus the specified requirement of ≤ 3.5) x full power background.
05 This event did not affect the health and safety of the public.
06
07
08 Technical Specifications 3.3.1, 3.3.2, 6.9.1.9b

09 | SYSTEM CODE IA (11) | CAUSE CODE E (12) | CAUSE SUBCODE E (13) | COMPONENT CODE INSTRU (14) | COMP. SUBCODE X (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR 83 | — | SEQUENTIAL REPORT NO. 032 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER C080 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The K603 alignment setpoint and the alarm setpoint were found out of calibration
11 causing the instrument to actuate out of specification. The K603A, Model No.
12 238X660G003 was calibrated and PT-1.1.12PC was satisfactorily completed. No further
13 action regarding this event is planned.
14

15 | FACILITY STATUS E (28) | % POWER 099 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Periodic Test

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA (43)

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA

8304130385 830405
PDR ADOCK 05000324
S PDR

NRC USE ONLY

NAME OF PREPARER M. J. Pastva, Jr. PHONE: 919-457-9521

GPO 917-926