



State of New Jersey
Department of Environmental Protection

Robert C. Shinn, Jr.
Commissioner

Division of Environmental Safety, Health,
and Analytical Programs
Radiation Protection Programs
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625-0415
Tel (609) 987-2032
Fax (609) 987-6354

September 15, 1994

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Hope Creek Generating Station
Docket No. 50-354
License Change Request LCR 94-08, 94-11, and 94-12
SSWS/SACS/EDG AOT Extensions and EDG Online
Maintenance

By letter dated July 27, 1994, Public Service Electric and Gas Company submitted the subject amendment to the Nuclear Regulatory Commission. This request proposes to revise the Allowed Out-of-service Times (AOTs) for inoperable Station Service Water System (SSWS) pumps, for inoperable Safety Auxiliaries Cooling System (SACS) pumps, and inoperable Emergency Diesel Generators (EDGs). In addition, this request is also proposing to allow online maintenance of the EDGs.

The New Jersey Department of Environmental Protection's Bureau of Nuclear Engineering reviewed the above amendment in accordance with the requirements of 10CFR50.91(b), and has no comments.

If you have any questions, please contact Suren Singh at (609) 987-2039 or Rich Pinney at (609) 987-2086.

Sincerely,

Kent Tosch, Manager
Bureau of Nuclear Engineering

230042

JE251/0

c: Assistant Director Lipoti
Radiation Protection Programs
N.J. DEP

Dave Moran
Acting NRC Project Manager

D. Chawaga
NRC Region I State Liaison

C. Marschall
Artificial Island Senior Resident Inspector

F. Thomson
Manager, Licensing and Regulation
PSE&G