



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

April 8, 1983

JAMES P. McGAUGHY, JR.
VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator


Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Special Report 83-016/0 - Fire
Door Blocked Open
AECM-83/0221

On March 2, 1983, fire door 1A202 (RHR 'A' Heat Exchanger Room) was blocked open to allow routing of a supply hose used in the performance of a hydrostatic test on a portion of the RHR system. An hourly firewatch was conducted in the area for the duration of the event in accordance with Technical Specification 3.7.7.

The condition had no effect on the health and safety of the public and did not constitute a threat to plant safety. The fire door was closed and returned to normal service at 2400 hours on March 14, 1983. Total time in the Limiting Condition for Operation was 12 days and 19 hours. This is a Special Report submitted pursuant to Technical Specification 6.9.2.

Yours truly,


FOR J.P. McGaughy, JR.

JPM:sap

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. T. B. Conner
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8304130429 830408
PDR ADDCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22

83 APR 11 4 9:50

REGION II
ATLANTA, GEORGIA