

Duquesne Light Company

Beaver Valley Power Station
PO Box 4
Shippingport, PA 15677-0004

JOHN D. SIEBER
Vice President - Nuclear Group

(412) 393-6266

April 12, 1991

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Subject: Beaver Valley Power Station, Unit No. 2
Docket No. 50-412, License No. NPF-73
Proposed Operating License Change Request No. 47
(TAC No. 80041)


Enclosed are the following:

1. An application for amendment to the above license to revise the required surveillance frequency from quarterly to refueling for those slave relays which satisfy certain screening criteria as specified in Table 4.3-2 of surveillance requirement 4.3.2.1.1.
2. Documents designated Attachments A, B, C and D, which set forth respectively, the change in the technical specifications, the safety analysis (including the no significant hazards evaluation), the typed replacement Technical Specification pages, and the applicable Updated Final Safety Analysis Report changes.

This change has been reviewed by the Onsite Safety Committee and Offsite Review Committee and was determined to be safe based on the attached safety analysis.

The requested target date for approval of this proposed change is August 1, 1991.

Sincerely,


J. D. Sieber
Vice President
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. A. W. DeAgazio, Project Manager
Mr. T. M. Gerusky, Director BRP/DER
Mr. R. Janati, BRP/DER
Mr. R. Saunders (VEPCO)

9104290052 910412
PDR ADOCK 05000412
P PDR

ADD