

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

Application of SOUTHERN CALIFORNIA	)	Docket No. 50-361
EDISON COMPANY, <u>ET AL.</u> for a Class 103	)	
License to Acquire, Possess, and Use	)	
a Utilization Facility as Part of	)	Amendment Application
Unit 2 of the San Onofre Nuclear	)	No. 130
Generating Station	)	

SOUTHERN CALIFORNIA EDISON COMPANY, ET AL. pursuant to 10 CFR 50.90, hereby submit Amendment Application No. 130.

This amendment application consists of proposed Technical Specification Change No. NPF-10-329 to Facility Operating License No. NPF-10. Proposed Technical Specification Change NPF-10-329 will revise Technical Specification 3/4.7.1.1, "Turbine Cycle." This proposed change will increase the as-found setpoint tolerance for the Main Steam Safety Valves (MSSVs) from +/-1% to +2%/-3%. The existing ACTION statement will be revised to require HOT STANDBY SHUTDOWN instead of HOT COLD SHUTDOWN. ~~Table 3.7-2 will be revised to require a reduction in steady state operating power with MSSVs INOPERABLE.~~ Also included in this proposed change are several editorial, format, and Bases changes which clarify the intent of this TS.

Supp 1

Subscribed on this 22nd day of SEPTEMBER 1994.

Respectfully submitted,

SOUTHERN CALIFORNIA EDISON COMPANY

By: Richard M. Rosenblum  
Richard. M. Rosenblum  
Vice President

State of California

County of Orange

On 9/22/94 before me, BARBARA A. MCCARTHY <sup>NOTARY PUBLIC</sup>, personally appeared RICHARD M. ROSENBLUM, personally known to me to be the person whose name is subscribed to the within instrument and acknowledged to me that he executed the same in his authorized capacity, and that by his signature on the instrument the person, or the entity upon behalf of which the person acted, executed the instrument.

WITNESS my hand and official seal.

Signature Barbara A. McCarthy

