

**BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION**

In the matter of
NEW YORK POWER AUTHORITY
James A. FitzPatrick Nuclear Power Plant

)
) Docket No. 50-333
)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the New York Power Authority, as holder of Facility Operating License No. DPR-59, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.


The proposed change to the James A. FitzPatrick Technical Specifications adds two new sections, 3.11.F and 4.11.F, and their associated Bases. These specifications add operability and surveillance requirements for ventilation and air conditioning (HVAC) equipment associated with four environmental enclosures.

The enclosures are installed around two 600 VAC electrical load centers and the two LPCI independent power supply charger/inverters. The load centers and charger/inverters are required to be operable under post-accident conditions. This equipment is not qualified to withstand the local post-accident environment. Therefore, enclosures around this equipment were installed to maintain a controlled atmosphere to protect the equipment from postulated harsh environments.

The proposed amendment to the Technical Specifications revises pages 242, 244, and the Table of Contents on page iii.

The proposed changes to the Technical Specifications are Attachment I to this Application for Amendment to the Operating License. The Safety Evaluation for the proposed changes is included as Attachment II.


New York Power Authority



Ralph E. Beedie
Executive Vice President
Nuclear Generation

**STATE OF NEW YORK
COUNTY OF WESTCHESTER**

Subscribed and sworn to before me
this 19 day of April 1991.



Notary Public

BARBARA ANN TAGGART
NOTARY PUBLIC, State of New York
No. 4851437
Qualified in Putnam County
Commission Expires Jan. 27, 1992

9104290226 910419
PDR ADDCK 05000333
P PDR