

Omaha Public Power District
1623 Harney Omaha, Nebraska 68102
402/536-4000

April 5, 1983
LIC-83-078

Mr. Robert A. Clark, Chief
U. S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
Division of Licensing
Operating Reactors Branch No. 3
Washington, D.C. 20555

Reference: Docket No. 50-285


Dear Mr. Clark:

NUREG-0737, Item II.F.1.6
Containment Hydrogen Monitors

Omaha Public Power District's letter and attached Licensee Event Report (LER 82-017) to the Commission dated October 1, 1982, identified the valve failures associated with one of the two containment hydrogen monitors. VA-81A was isolated following the valve failures pending completion of repairs.

The valve failures were originally traced to damaged solenoid coils. Further investigation has shown the cause to be failure of the Conax feed-through assemblies. The faulty assemblies have been replaced and VA-81A has been returned to service.

Sincerely,



W. C. Jones
Division Manager
Production Operations

WCJ/TLP:jmm

cc: LeBoeuf, Lamb, Leiby & MacRae
1333 New Hampshire Avenue, N.W.
Washington, D.C. 20036

Mr. L. A. Yandell, NRC
Senior Resident Inspector

8304150127 830405
PDR ADOCK 05000285
S PDR

A046