



Northeast
Utilities System

107 Selden Street, Berlin, CT 06037

Northeast Utilities Service Company
P.O. Box 270
Hartford, CT 06141-0270
(203) 665-5000

September 21, 1994

Docket No. 50-336
B14924

Re: 10CFR50.90

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station, Unit No. 2
Proposed Revision to Technical Specifications
Generic Letter 90-06

The purpose of this letter is to request a revision to a proposed license amendment which Northeast Nuclear Energy Company (NNECO) submitted to the NRC Staff on April 25, 1994,⁽¹⁾ on behalf of Millstone Unit No. 2.

On April 25, 1994, NNECO submitted a proposed license amendment to the NRC to address Generic Letter (GL) 90-06 and other related issues. The topics addressed in that letter were: (1) power-operated relief valve and block valve reliability; (2) low-temperature overpressure protection; (3) boron dilution; and (4) shutdown risk management.

Currently, NNECO is developing proposed procedure modifications in anticipation of the NRC acceptance of the proposed license amendment. During the course of the procedure modifications, NNECO identified that the proposed modification to Surveillance Requirement 4.4.3.2 was not as clear as it could be. Surveillance Requirement 4.4.3.2, in our April 25, 1994, letter, states in part, "This demonstration is not required if a PORV block valve is closed and power removed to meet Specification 3.4.3 b, c or d." NNECO believes that this section should be revised to cite only Action Statement "b" or "c" of Limiting Condition for Operation (LCO) 3.4.3 and should now read in part, "This demonstration is not required if a PORV block valve is closed and power removed to meet Specification 3.4.3 b or c." Action Statement "d" in LCO 3.4.3 is correct as proposed and

-
- (1) J. F. Opeka letter to the U.S. Nuclear Regulatory Commission, "Proposed Revision to Technical Specifications, Generic Letter 90-06," dated April 25, 1994.

AD19

U.S. Nuclear Regulatory Commission
B14924/Page 2
September 21, 1994


follows the guidance of GL 90-06. The permissive of Surveillance Requirement 4.4.3.2 (i.e., closed and power removed) would not be able to be met by following action "d", therefore, Surveillance Requirement 4.4.3.2 should be modified accordingly. NNECO also has deleted Action Statement "e" and Action Statement "f" from LCOs 3.4.3 and 3.4.9.3, respectively. These action statements are not required since Technical Specification 3.0.4 has previously been modified and adequately addresses this issue.

NNECO has attached marked up and retyped pages of the Millstone Unit No. 2 Technical Specifications. They are included as Attachments 1 and 2, respectively. These pages should replace those pages transmitted in our April 25, 1994, letter. The Safety Assessment, Significant Hazards Consideration, Environmental Impact Statement, and overall conclusion contained in our April 25, 1994, letter remain valid and are unaffected by this proposed revision.

If you should have any questions on the above or attached, please contact Mr. R. H. Young (203) 665-3717.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY




J. F. Opeka
Executive Vice President

cc: T. T. Martin, Region I Administrator
G. S. Vissing, NRC Project Manager, Millstone Unit No. 2
P. D. Swetland, Senior Resident Inspector, Millstone Unit
Nos. 1, 2, and 3

Mr. Kevin T.A. McCarthy, Director
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
P.O. Box 5066
Hartford, CT 06102-5066

Subscribed and sworn to before me

this 21st day of September, 1994



Date Commission Expires: 3/31/98