


**Mailing Address**  
Alabama Power Company  
600 North 18th Street  
Post Office Box 2641  
Birmingham, Alabama 35291  
Telephone 205 783-6081

**F. L. Clayton, Jr.**  
Senior Vice President  
Flintridge Building



March 11, 1983

Docket No. 50-364

Director, Office of Management  
Information and Program Control  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555


Dear Sir:

**RE: Joseph M. Farley Nuclear Plant  
Unit 2  
Monthly Operating Data Report**

Attached are two (2) copies of the February, 1983 Monthly Operating Report for Joseph M. Farley Nuclear Plant, Unit 2, required by Section 6.9.1.10 of the Unit 2 Technical Specifications. As requested by letter from Mr. John F. Stolz to Mr. Alan R. Barton, dated October 21, 1977, a "Narrative Summary of Operating Experience" is included in the attached report.

If you have any questions, please advise.

Yours very truly,

  
F. L. Clayton, Jr.

FLCJr/KWM:nac

Enclosures

xc: Mr. Ted Cintula (1 copy)  
Director, IE (10 copies)  
Director, RII (1 copy)

**IE24**

JOSEPH M. FARLEY NUCLEAR PLANT  
UNIT 2  
NARRATIVE SUMMARY OF OPERATIONS  
FEBRUARY, 1983

The Unit experienced no shutdowns or significant power reductions during the month of February.

The following safety-related maintenance was performed in the month of February.

1. Performed miscellaneous maintenance on diesel generators.
2. Replaced Waste Evaporator Feed Filter Q2G21F003.
3. Replaced broken handle on Service Water Valve Q2P16V560 Manual Operator.
4. Replaced seal injection filter Q2E21F004B.