

Duke Power Company
McGuire Nuclear Generation Department
12700 Hagers Ferry Road (MG01VP)
Huntersville, NC 28078-8985

T. C. McMEEKIN
Vice President
(704)875-4800
(704)875-4809 Fax



DUKE POWER

September 15, 1994

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington D.C. 20555

Subject: McGuire Nuclear Station, Units 1 and 2
Dockets Nos. 50-369 and 50-370
Revision to Technical Specification Bases

Gentlemen:

This letter details a revision to the McGuire Nuclear Station Technical Specification Bases entitled "Refueling Operations; Instrumentation" (Technical Specification Bases 3/4.9.2). The revision allows the use of newly installed Wide Range Neutron Flux Monitors while in Mode 6 to insure that redundant monitoring capability is available to detect changes in the reactivity condition of the core. These monitors will be used in addition to the two existing source range monitors (N-31 and N-32) presently employed for this reactivity monitoring.

Any questions pertaining to this matter should be directed to Dwin Caldwell at 704-875-4328.

Very truly yours,

Ted McMeekin

cc: Mr. Victor Nerses, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
One White Flint North, Mail Stop 9H3
Washington, D. C. 20555

Mr. S. D. Ebnetter
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta St. NW Suite 2900
Atlanta, Georgia 30323

Mr. Bob Martin
U.S. Nuclear Regulatory Commission
Office of Nuclear Reactor Regulation
One White Flint North, Mail Stop 9H3
Washington, D. C. 20555


Mr. George Maxwell, Senior Resident Inspector
McGuire Nuclear Station

9409290312 940915
PDR ADOCK 05000369
P PDR

A001
1/1


U.S. Nuclear Regulatory Commission
September 15, 1994
Page 2

T. C. McMeekin, being duly sworn, states that he is Vice President, McGuire Nuclear Generation Department, Duke Power Company; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission this revision to the McGuire Nuclear Station Final Safety Analysis Report and that all statements and matter set forth therein are true and correct to the best of his knowledge.



T. C. McMeekin, Vice President
McGuire Nuclear Station

Subscribed and sworn to me this 19th day of September, 1994.


Notary Public

My Commission expires:

12/13/98

U.S. Nuclear Regulatory Commission
September 15, 1994

bxc: A. V. Carr
 N',RB Staff
 J. F. Snyder
 R. J. Deese
 J. E. Burchfield
 Z. L. Taylor
 V. M. Coren
 ELL (EC050)
 RC Group File: 801.01
 P. R. Herran
 T. D. Curtis
 R. A. Jones
 R. B. White
 R. B. Travis
 G.A Copp III