

3/4.9 REFUELING OPERATIONSBASES3/4.9.1 BORON CONCENTRATION

The limitations on reactivity conditions during REFUELING ensure that: (1) the reactor will remain subcritical during CORE ALTERATIONS, and (2) a uniform boron concentration is maintained for reactivity control in the water volume having direct access to the reactor vessel. These limitations are consistent with the initial conditions assumed for the boron dilution incident in the accident analyses. The value of 0.95 or less for K_{eff} includes a 1% delta k/k conservative allowance for uncertainties. Similarly, the boron concentration value of 2000 ppm or greater includes a conservative uncertainty allowance of 50 ppm boron.

The Reactor Makeup Water Supply to the Chemical and Volume Control (NV) System is normally isolated during refueling to prevent diluting the Reactor Coolant System boron concentration. Isolation is normally accomplished by closing valve NV-250. However, isolation may be accomplished by closing valves NV-131, NV-140, NV-176, NV-468, NV-808, and either NV-132 or NV-1026, when it is necessary to makeup water to the Refueling Water Storage Tank during refueling operations.

3/4.9.2 INSTRUMENTATION

The OPERABILITY of the Source Range Neutron Flux Monitors ensures that redundant monitoring capability is available to detect changes in the reactivity condition of the core. ←

Add

3/4.9.3 DECAY TIME

The minimum requirement for reactor subcriticality prior to movement of irradiated fuel assemblies in the reactor vessel ensures that sufficient time has elapsed to allow the radioactive decay of the short-lived fission products. This decay time is consistent with the assumptions used in the accident analyses.

3/4.9.4 CONTAINMENT BUILDING PENETRATIONS

The requirements on containment building penetration closure and OPERABILITY of the Reactor Building Containment Purge Exhaust System HEPA filters and charcoal adsorbers ensure that a release of radioactive material within containment will be restricted from leakage to the environment or filtered through the HEPA filters and charcoal adsorbers prior to discharge to the atmosphere. The OPERABILITY and closure restrictions are sufficient to restrict radioactive material release from a fuel element rupture based upon the lack of containment pressurization potential while in the REFUELING MODE. Operation of the Reactor Building Containment Purge Exhaust System HEPA filters and charcoal adsorbers and the resulting iodine removal capacity are consistent with the assumptions of the accident analysis. The methyl iodide penetration test criteria for the carbon samples have been made more restrictive than required for the assumed iodine removal in the accident analysis because the humidity to be seen by the charcoal adsorbers may be greater than 70% under normal operating conditions.

→ In MODE 6 the Wide Range Neutron Flux Detectors (ENC) can be used as Source Range Neutron Flux Monitors. All of the LCO, ACTION, and SURVEILLANCE REQUIREMENTS of 3/4.9.2 must be met for the two Source Range Neutron Flux Monitors that are in use at any time.